


COOLANT REPORT

COLORADO/443 45.49L [COLORADO^443]

Radiator Coolant

CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)





Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

All metal levels are normal indicating no corrosion in the cooling system.

Contamination

There is no indication of any contamination in the coolant.


Fluid Condition


Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

G/12)						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0883934	WC0859605	WC0766208
Sample Date		Client Info		03 Apr 2024	20 Nov 2023	10 Mar 2023
Machine Age	hrs	Client Info		16323	15989	15516
Oil Age	hrs	Client Info		16323	15989	15516
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water	•	WC Method		NEG	NEG	NEG
PHYSICAL TEST R	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.067	1.067	1.066
pH	Scale 0-14	ASTM D1287		8.59	8.65	8.70
Nitrites	ppm	AP-053:2009		1012	864	1012
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.3	49.2	48.8
Freezing Point	°F	ASTM D3321		-33	-33	-31
Total Dissolved Solids				334.5	372.0	396.0
Carboxylate				fail	pass	fail
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	<1	<1	21
Phosphorus	ppm	ASTM D6130	0	0	4	4
Boron	ppm	ASTM D6130	0	0	0	0
Molybdenum	ppm	ASTM D6130	950	692	609	1200
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130		0	0	0
Aluminum	ppm	ASTM D6130		1	<1	<1
Copper	ppm	ASTM D6130		<1	<1	<1
Lead	ppm	ASTM D6130		<1	<1	<1
Tin	ppm	ASTM D6130		<1	2	<1
Zinc	ppm	ASTM D6130		0	1	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		5	11	4
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		4596	3774	6545
Potassium	ppm	ASTM D6130		377	324	835
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		<1	2	2
Magnesium	ppm	ASTM D6130		<1	1	0
magnooiam	PPIII	AOTHI DOTO			,	U



COOLANT REPORT









Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06142668

: WC0883934 Unique Number : 10967476

Received : 08 Apr 2024 **Tested** Diagnosed

: 11 Apr 2024 : 11 Apr 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, ICP)

SHERWOOD CONSTRUCTION CO INC 3219 WEST MAY ST WICHITA, KS US 67213 Contact: BILL ORCUTT

william.orcutt@wildcat.net

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: BRANDEN JAQUIAS

T:

F: