


## **COOLANT REPORT**



COLORADO/443/SKIDSTEER 53.173L [COLORADO^443^SKIDSTEER] Component

Fluid CATERPILLAR ELC (4





## DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.


#### **Coolant Condition**


Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


GAL)		Dec	<u>1</u> -2022	Dec2023 Apr20	124	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0883942	WC0859583	WC0741776
Sample Date		Client Info		03 Apr 2024	04 Dec 2023	13 Dec 2022
Machine Age	hrs	Client Info		1242	1102	3
Oil Age	hrs	Client Info		1242	1102	3
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.067	1.066	1.066
рΗ	Scale 0-14	ASTM D1287		9.14	9.31	8.40
Nitrites	ppm	AP-053:2009		524	560	748
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.6	49.0	48.9
Freezing Point	°F	ASTM D3321		-33	-33	-31
Total Dissolved Solids				286.5	318.0	340.5
Carboxylate				fail	fail	fail
CORROSION INHI	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	2	18	32
Phosphorus	ppm	ASTM D6130	0	0	0	86
Boron	ppm	ASTM D6130	0	0	0	6
Molybdenum	ppm	ASTM D6130	950	545	154	889
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	0	0	<1
Aluminum	ppm	ASTM D6130	>10	3	6	<1
Copper	ppm	ASTM D6130	>10	<1	<1	<1
Lead	ppm	ASTM D6130	>10	<1	<1	<1
Tin	ppm	ASTM D6130	>10	<1	<1	<1
Zinc	ppm	ASTM D6130		0	0	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		16	19	35
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		3662	3142	5557
Potassium	ppm	ASTM D6130		563	904	541
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calaium	nnm	ASTM D6130		•	.4	4
Calcium	ppm	ASTIVI DO 130		0	<1	4



# **COOLANT REPORT**











Certificate 12367

Laboratory Sample No.

: WC0883942 Lab Number : 06142671 Unique Number : 10967479

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** 

: 08 Apr 2024 Diagnosed

: 11 Apr 2024 : 11 Apr 2024 - Jonathan Hester

SHERWOOD CONSTRUCTION CO INC 3219 WEST MAY ST WICHITA, KS US 67213

Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP )

Contact: BILL ORCUTT william.orcutt@wildcat.net T: (719)499-6303

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SHEWIC [WUSCAR] 06142671 (Generated: 04/15/2024 12:26:46) Rev: 1

Submitted By: BRANDEN JAQUIAS

F: x: