




# COOLANT REPORT

## Sample Rating Trend



**NORMAL**



Machine Id  
**AMBER RIDGE**

Component  
**Coolant**  
Fluid  
**EXTENDED LIFE COOLANT (--- GAL)**

### DIAGNOSIS

#### Recommendation

The fluid is suitable for further service.

#### Contaminants

There is no indication of any contamination in the coolant.

#### Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.







### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0789426</b>	WC0700361	WCM1389048
Sample Date	Client Info		<b>04 Apr 2024</b>	10 Jun 2022	15 Sep 2020
Machine Age	hrs	Client Info	<b>337</b>	290	239
Oil Age	hrs	Client Info	<b>337</b>	290	0
Oil Changed		Client Info	<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

### PHYSICAL TEST RESULTS








	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		<b>1.067</b>	1.079	---
pH	Scale 0-14 ASTM D1287		<b>10.5</b>	8.93	8.96
Nitrites	ppm AP-053:2009		<b>1012</b>	1200	976
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		<b>49.5</b>	59.9	59
Freezing Point	°F ASTM D3321		<b>-33</b>	-56	-63
Total Dissolved Solids			<b>300.5</b>	372.0	376.0
Carboxylate			<b>n/a</b>	n/a	n/a

### VISUAL

	method	limit/base	current	history1	history2
Coolant Color	*Visual		<b>Green</b>	Yellow	Orange
Coolant Appearance	*Visual	Clear	<b>normal</b>	normal	normal
Color					
Bottom					



# COOLANT REPORT



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0789426  
**Lab Number** : 06142690  
**Unique Number** : 10967498  
**Test Package** : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType )

**Received** : 08 Apr 2024  
**Tested** : 11 Apr 2024  
**Diagnosed** : 11 Apr 2024 - Jonathan Hester

**ALTERNATIVE POWER**  
 1000 NORTHGATE CT  
 MORRISVILLE, NC  
 US 27560

Contact: TERESA CHESTER  
 teresa.chester@bittingelectric.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: