




COOLANT REPORT

Sample Rating Trend



NORMAL



Machine Id
AMBER ACRES
 Component
Coolant
 Fluid
HYBRID (HOAT) COOLANT (--- GAL)

DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0789419	WCM1389102	---
Sample Date	Client Info		04 Apr 2024	24 Sep 2020	---
Machine Age	hrs	Client Info	173	72	---
Oil Age	hrs	Client Info	173	0	---
Oil Changed		Client Info	N/A	N/A	---
Sample Status			NORMAL	NORMAL	---

PHYSICAL TEST RESULTS








	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		1.064	---	---
pH	Scale 0-14 ASTM D1287		7.80	7.51	---
Nitrites	ppm AP-053:2009		864	936	---
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		47.5	47	---
Freezing Point	°F ASTM D3321		-28	-31	---
Total Dissolved Solids			433.0	510.0	---
Carboxylate			n/a	n/a	---

VISUAL

	method	limit/base	current	history1	history2
Coolant Color	*Visual		Yellow	Yellow	---
Coolant Appearance	*Visual	Clear	normal	normal	---
Color					no image
Bottom					no image



COOLANT REPORT



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0789419
Lab Number : 06142692
Unique Number : 10967500
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

Received : 08 Apr 2024
Tested : 11 Apr 2024
Diagnosed : 11 Apr 2024 - Jonathan Hester

ALTERNATIVE POWER
 1000 NORTHGATE CT
 MORRISVILLE, NC
 US 27560

Contact: TERESA CHESTER
 teresa.chester@bittingelectric.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: