

# **PROBLEM SUMMARY**

Sample Rating Trend


ISO

# NORRIS A

Component Hydraulic System

BELRAY AW 100 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS									
Sample Status			SEVERE						
Particles >4µm	ASTM D7647	>5000	<b>46727</b>						
Particles >6µm	ASTM D7647	>1300	<b>^</b> 7673						
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>23/20/14</b>						

Customer Id: VELHEN Sample No.: TO10002261 Lab Number: 06143027 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component.			
Resample			?	Resample in 30-45 days to monitor this situation.			
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			
Check Seals			?	Check seals and/or filters for points of contaminant entry.			

# HISTORICAL DIAGNOSIS



# **OIL ANALYSIS REPORT**

# Sample Rating Trend ISO

# NORRIS A

Hydraulic System

BELRAY AW 100 (--- GAL)

## DIAGNOSIS

### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

			Apr <b>2</b> 024				
CAMPLE INFORM	AATION		11 11 11				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		TO10002261			
Sample Date		Client Info		03 Apr 2024			
Machine Age	hrs	Client Info		0			
Oil Age	hrs	Client Info		0			
Oil Changed		Client Info		Not Changd			
Sample Status				SEVERE			
WEAR METALS		method	limit/base	current	history1	history2	
ron	ppm	ASTM D5185m	>20	<1			
Chromium	ppm	ASTM D5185m	>20	0			
Nickel	ppm	ASTM D5185m	>20	0			
Γitanium	ppm	ASTM D5185m		0			
Silver	ppm	ASTM D5185m		0			
Aluminum	ppm	ASTM D5185m	>20	0			
_ead	ppm	ASTM D5185m	>20	0			
Copper	ppm	ASTM D5185m	>20	3			
Γin	ppm	ASTM D5185m	>20	<1			
/anadium	ppm	ASTM D5185m		<1			
Cadmium	ppm	ASTM D5185m		0			
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0			
Barium	ppm	ASTM D5185m		0			
Molybdenum	ppm	ASTM D5185m		0			
Manganese	ppm	ASTM D5185m		<1			
Magnesium	ppm	ASTM D5185m		1			
Calcium	ppm	ASTM D5185m		55			
Phosphorus	ppm	ASTM D5185m		237			
Zinc	ppm	ASTM D5185m		287			
Sulfur	ppm	ASTM D5185m		957			
CONTAMINANTS	• •	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	<1			
Sodium	ppm	ASTM D5185m	>10	<1			
Potassium	ppm	ASTM D5185m	>20	0			
Vater	%	ASTM D6304	>0.05	0.004			
opm Water	ppm	ASTM D6304	>500	41			
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>5000	<b>46727</b>			
Particles >6µm		ASTM D7647	>1300	▲ 7673			
Particles >14µm		ASTM D7647	>160	108			
Particles >21μm		ASTM D7647	>40	100			
Particles >38μm		ASTM D7647	>10	0			
Particles >36μm		ASTM D7647	>3	0			
Particles >7 τμπ Dil Cleanliness		ISO 4406 (c)	>19/17/14	△ 23/20/14			
FLUID DEGRADA	TION -						
		method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.25			



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

Lab Number

: TO10002261 : 06143027 Unique Number : 10967835

Received : 09 Apr 2024 **Tested** : 10 Apr 2024

Diagnosed : 10 Apr 2024 - Wes Davis

Test Package : IND 2 (Additional Tests: KF, KV100, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (903)807-9576 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: VELHEN [WUSCAR] 06143027 (Generated: 04/10/2024 11:55:31) Rev: 1

Contact/Location: AARON NILSSON - VELHEN

P.O. BOX 993

US 75653

HENDERSON, TX

Contact: AARON NILSSON

awn.nilsson@icloud.com