




PROBLEM SUMMARY


Area
610 LYO [3027196]
 Machine Id
14T03
 Component
Hydraulic System
 Fluid
TEXACO AW 68 (18 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

| Sample Status | ASTM D7647 | SEVERE | ABNORMAL | ABNORMAL |
|-----------------|------------------------|------------|------------|------------|
| Particles >4µm | >5000 | ▲ 38205 | ▲ 248665 | ▲ 145182 |
| Particles >6µm | >1300 | ▲ 7186 | ▲ 187239 | ▲ 23100 |
| Particles >14µm | >160 | ▲ 877 | ▲ 70135 | ▲ 5125 |
| Particles >21µm | >40 | ▲ 372 | ▲ 31687 | ▲ 2616 |
| Particles >38µm | >10 | ▲ 38 | ▲ 4575 | ▲ 77 |
| Oil Cleanliness | ISO 4406 (c) >19/17/14 | ▲ 22/20/17 | ▲ 25/25/23 | ▲ 24/22/20 |

Customer Id: TALCLA
 Sample No.: WC0907805
 Lab Number: 06143036
 Test Package: IND 2



To manage this report scan the QR code







To discuss the diagnosis or test data:
 Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|-------------------|--------|------|---------|--|
| Change Filter | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |
| Resample | --- | --- | ? | Resample in 30-45 days to monitor this situation. |
| Check Breathers | --- | --- | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Dirt Access | --- | --- | ? | We advise that you check all areas where contaminants can enter the system. |
| Filter Fluid | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |


HISTORICAL DIAGNOSIS

| | | |
|--|--|--|
| <p>ISO</p>  | <p>01 Mar 2022 Diag: Angela Borella The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.</p> | <p>view report</p>  |
| <p>ISO</p>  | <p>18 Feb 2021 Diag: Don Baldrige We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.</p> | <p>view report</p>  |
| <p>DIRT</p>  | <p>19 Feb 2020 Diag: Jonathan Hester The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.</p> | <p>view report</p>  |



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
610 LYO [3027196]
 Machine Id
14T03
 Component
Hydraulic System
 Fluid
TEXACO AW 68 (18 GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0907805 | WC0664334 | WC0525125 |
| Sample Date | Client Info | | 07 Apr 2024 | 01 Mar 2022 | 18 Feb 2021 |
| Machine Age | mths | Client Info | 0 | 0 | 0 |
| Oil Age | mths | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | Not Changd | Not Changd |
| Sample Status | | | SEVERE | ABNORMAL | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >20 | 3 | 6 | 2 |
| Chromium | ppm | ASTM D5185m >10 | 0 | <1 | <1 |
| Nickel | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >10 | 0 | <1 | 0 |
| Lead | ppm | ASTM D5185m >20 | 0 | <1 | 0 |
| Copper | ppm | ASTM D5185m >20 | 2 | 4 | 2 |
| Tin | ppm | ASTM D5185m >10 | <1 | 2 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | <1 | <1 |
| Barium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 0 | 0 | <1 |
| Calcium | ppm | ASTM D5185m | 25 | 29 | 23 |
| Phosphorus | ppm | ASTM D5185m | 139 | 216 | 141 |
| Zinc | ppm | ASTM D5185m | 117 | 337 | 118 |
| Sulfur | ppm | ASTM D5185m | 2585 | 2095 | 1916 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >15 | 2 | 6 | 2 |
| Sodium | ppm | ASTM D5185m | 2 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 7 | 0 | 0 |
| Water | % | ASTM D6304 >0.05 | 0.021 | 0.016 | 0.018 |
| ppm Water | ppm | ASTM D6304 >500 | 211 | 162.6 | 182.2 |

FLUID CLEANLINESS






| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >5000 | ▲ 38205 | ▲ 248665 | ▲ 145182 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 7186 | ▲ 187239 | ▲ 23100 |
| Particles >14µm | ASTM D7647 | >160 | ▲ 877 | ▲ 70135 | ▲ 5125 |
| Particles >21µm | ASTM D7647 | >40 | ▲ 372 | ▲ 31687 | ▲ 2616 |
| Particles >38µm | ASTM D7647 | >10 | ▲ 38 | ▲ 4575 | ▲ 77 |
| Particles >71µm | ASTM D7647 | >3 | 3 | ▲ 177 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | ▲ 22/20/17 | ▲ 25/25/23 | ▲ 24/22/20 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.20 | 0.22 | 0.202 |




OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | LIGHT | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46.0 | 47.6 | 48.0 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0907805 **Received** : 09 Apr 2024
Lab Number : 06143036 **Tested** : 10 Apr 2024
Unique Number : 10967844 **Diagnosed** : 10 Apr 2024 - Wes Davis
Test Package : IND 2 (Additional Tests: KF)

GRIFOLS TALECRIS PHARMACEUTICAL
 8368 US 70 WEST
 CLAYTON, NC
 US 27520
 Contact: KEN TERRY
 kenneth.terry@grifols.com
 T: (919)359-4362
 F: (919)359-4767

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)