


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AIRCENTER SX 7.5 4750238 (S/N 1055)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016385	KCP39893	KCP27765
Sample Date		Client Info		26 Mar 2024	27 Oct 2021	07 Jan 2021
Machine Age	hrs	Client Info		11122	5084	3736
Oil Age	hrs	Client Info		3677	1348	1436
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	4	2	2
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	9	0
Barium	ppm	ASTM D5185m	90	0	4	11
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	14	48	66
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	<1	<1	5
Zinc	ppm	ASTM D5185m	0	17	3	0
Sulfur	ppm	ASTM D5185m	23500	22026	16789	17679
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		12	13	17
Potassium	ppm	ASTM D5185m	>20	<1	<1	2
Water	%	ASTM D6304	>0.05	0.002	0.009	0.014
ppm Water	ppm	ASTM D6304	>500	25	93.0	144.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9222	9027	3975
Particles >6µm		ASTM D7647		<u> </u>	1729	1398
Particles >14µm		ASTM D7647	>80	<u> </u>	78	84
Particles >21µm		ASTM D7647	>20	27	16	19
Particles >38µm		ASTM D7647	>4	2	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/15	18/13	18/14



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 10967903

: KCPA016385 : 06143095

Received : 09 Apr 2024 **Tested** Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 10 Apr 2024 : 11 Apr 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: Service Manager - PILBRO

12300 PILATUS WAY

Contact: Service Manager

BROOMFIELD, CO

US 80021

T: