




OIL ANALYSIS REPORT



Machine Id
BRCM01BE (S/N GZJ00658)
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

Sample Rating Trend



DIRT



DIAGNOSIS

▲ Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition.

▲ Wear

The tin level is abnormal.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0760865	WC0760878	WC0760882
Sample Date	Client Info		05 Apr 2024	29 Mar 2024	21 Mar 2024
Machine Age	hrs	Client Info	75840	75691	75505
Oil Age	hrs	Client Info	400	161	65
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			ABNORMAL	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method		NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	0	0	<1
Chromium	ppm	ASTM D5185m >3	0	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >5	2	2	2
Lead	ppm	ASTM D5185m >8	<1	<1	<1
Copper	ppm	ASTM D5185m >5	<1	0	<1
Tin	ppm	ASTM D5185m >3	▲ 4	▲ 3	1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	6	7	8
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	9	7	8
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	36	29	35
Calcium	ppm	ASTM D5185m	1848	1804	1741
Phosphorus	ppm	ASTM D5185m	315	312	318
Zinc	ppm	ASTM D5185m	383	371	368
Sulfur	ppm	ASTM D5185m	1825	2245	1890

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	▲ 198	141	43
Sodium	ppm	ASTM D5185m >20	2	<1	2
Potassium	ppm	ASTM D5185m >20	0	0	2

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624	6.2	6.3	5.5
Sulfation	Abs/.1mm	*ASTM D7415	19.3	18.5	15.5


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	12.7	12.1	8.5
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	1.70	1.38	0.67
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	3.77	4.20	5.20




OIL ANALYSIS REPORT


Non-ferrous Metals




FT-IR (Direct Trend)




Acid Number



Acid Number











Base Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.1	12.8

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0760865
 Lab Number : 06143252
 Unique Number : 10968060
 Test Package : MOB 2

Received : 09 Apr 2024
 Tested : 10 Apr 2024
 Diagnosed : 10 Apr 2024 - Jonathan Hester

EDL NA Recips-Brown County
 BROWN COUNTY POWER STATION, 9427 BEYERS RD
 GEORGETOWN, OH
 US 45121
 Contact: MITCHELL BUTLER
 Mitchell.Butler@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)