

## **COOLANT REPORT**

Sample Rating Trend

### NORMAL

## CUMMINS PEAKL CLT (S/N D110203732) Component Coolant

Coolant Fluid

{not provided} (--- GAL)

#### DIAGNOSIS

Recommendation


The fluid is suitable for further service.

### Contaminants

There is no indication of any contamination in the coolant.

#### **Coolant Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.






SAMPLE INFORM	<b>1ATION</b>	method				history2
Sample Number		Client Info		WC0901692		
Sample Date		Client Info		09 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.071		
рН	Scale 0-14	ASTM D1287		8.75		
Nitrites	ppm	AP-053:2009		1464		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		53.4		
Freezing Point	°F	ASTM D3321		-43		
Total Dissolved Solids				433.0		
Carboxylate				n/a		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Green		
Coolant Appearance		*Visual	Clear	normal		
Color					no image	no image
Bottom				. 0	no image	no image



# **COOLANT REPORT**







Lab Number : 06143500 Tested : 12 Apr 2024 Unique Number : 10968308 Diagnosed : 12 Apr 2024 - Jonathan Hester Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType ) Contact: RALPH DICKSON IV Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. ralph\_dickson@dicksonap.com T: (704)860-7894 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Laboratory

Contact/Location: RALPH DICKSON IV - DICSHENC

F:

SHELBY, NC

US 28150