

## **COOLANT REPORT**

Sample Rating Trend

#### NORMAL

# BLUE STAR NHC LAURENS (S/N 116395-1-1)

Component Auxiliary Coolant Fluid

{not provided} (--- GAL)

#### DIAGNOSIS

**Recommendation** The fluid is suitable for further service.

### Contaminants

There is no indication of any contamination in the coolant.

#### **Coolant Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.







SAMPLE INFORM	1ATIO <u>N</u>	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0901695		
Sample Date		Client Info		09 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.072		
рН	Scale 0-14	ASTM D1287		8.42		
Nitrites	ppm	AP-053:2009		1616		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		53.5		
Freezing Point	°F	ASTM D3321		-43		
Total Dissolved Solids				190.5		
Carboxylate				n/a		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Pink		
Coolant Appearance		*Visual	Clear	normal		
Color					no image	no image
Bottom					no image	no image



## **COOLANT REPORT**







Contact/Location: RALPH DICKSON IV - DICSHENC