




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id

**C-30**

Component

**Rotary Compressor**

Fluid

**INGERSOLL-RAND TURBOBLEND 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0907821</b>	WC0907815	WC0820252
Sample Date	Client Info	<b>04 Apr 2024</b>	09 Mar 2024	06 Feb 2024
Machine Age	mths Client Info	<b>0</b>	0	0
Oil Age	mths Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >70	<b>0</b>	0	0
Chromium	ppm ASTM D5185m >10	<b>&lt;1</b>	<1	0
Nickel	ppm ASTM D5185m	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	<b>0</b>	<1	0
Silver	ppm ASTM D5185m	<b>0</b>	<1	0
Aluminum	ppm ASTM D5185m >3	<b>0</b>	0	0
Lead	ppm ASTM D5185m >4	<b>0</b>	1	0
Copper	ppm ASTM D5185m >20	<b>0</b>	0	0
Tin	ppm ASTM D5185m >3	<b>0</b>	<1	0
Vanadium	ppm ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>0</b>	0	0
Barium	ppm ASTM D5185m	<b>&lt;1</b>	0	<1
Molybdenum	ppm ASTM D5185m	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm ASTM D5185m	<b>0</b>	0	0
Calcium	ppm ASTM D5185m	<b>0</b>	0	8
Phosphorus	ppm ASTM D5185m	<b>1011</b>	910	1031
Zinc	ppm ASTM D5185m	<b>0</b>	0	0
Sulfur	ppm ASTM D5185m	<b>129</b>	0	32

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >45	<b>0</b>	<1	0
Sodium	ppm ASTM D5185m	<b>&lt;1</b>	<1	0
Potassium	ppm ASTM D5185m >20	<b>0</b>	1	0
Water	% ASTM D6304 >0.6	<b>0.003</b>	0.002	0.002
ppm Water	ppm ASTM D6304	<b>36</b>	16	22

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>336</b>	142	180
Particles >6µm	ASTM D7647 >2500	<b>55</b>	38	45
Particles >14µm	ASTM D7647 >320	<b>7</b>	5	5
Particles >21µm	ASTM D7647 >80	<b>3</b>	0	1
Particles >38µm	ASTM D7647 >20	<b>0</b>	0	0
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>16/13/10</b>	14/12/10	15/13/10

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.205</b>	0.08	0.092




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.0	44.0	43.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0907821 **Received** : 09 Apr 2024  
**Lab Number** : 06143706 **Tested** : 10 Apr 2024  
**Unique Number** : 10968514 **Diagnosed** : 12 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**UGI ENERGY SERVICES - LNG FACILITY**  
 80 ENERGY LN  
 MESHOPPEN, PA  
 US 18630  
 Contact: JOE BARRETT  
 jbarrett@ugies.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)