


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER AS 20T 3005833 (S/N 1303)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar201	8 Mar2022	Apr2023 Ma	w2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013900	KCPA002763	KCP38524
Sample Date		Client Info		21 Mar 2024	05 Apr 2023	25 Mar 2022
Machine Age	hrs	Client Info		85581	80868	76898
Oil Age	hrs	Client Info		3110	0	12795
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	15	31	<u>△</u> 98
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m	>10			
Vanadium		ASTM D5185m		0	0	0
	ppm			-		
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	<1	<1	3
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	2	0
Zinc	ppm	ASTM D5185m	0	28	2	0
Sulfur	ppm	ASTM D5185m	23500	19986	18286	10739
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.05	0.008	0.008	0.004
ppm Water	ppm	ASTM D6304	>500	81	82.1	43.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2467	5445	
Particles >6µm		ASTM D7647	>1300	638	1892	
Particles >14µm		ASTM D7647	>80	48	<u>193</u>	
Particles >21µm		ASTM D7647	>20	13	△ 59	
Particles >38µm		ASTM D7647	>4	0	4	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13	△ 20/18/15	
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

0.38



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number

: KCPA013900 : 06143727 Unique Number : 10968535

Received : 09 Apr 2024 **Tested** Diagnosed

: 10 Apr 2024 : 12 Apr 2024 - Jonathan Hester

NEW BOSTON, OH

Contact: SERVICE MANAGER WATERFILTRATION@PORTSMOUTHOH.ORG T:

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 4862 GULLIA ST

US 45662

F: