




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**SPLITTER 1**  
 Machine Id  
**078CM12002**  
 Component  
**Turbine**  
 Fluid  
**ROYAL PURPLE SYNFILM GT 32 (500 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0040980</b>	RP0027289	RP0027304
Sample Date	Client Info	<b>09 Apr 2024</b>	27 Jan 2024	10 Oct 2023
Machine Age	hrs Client Info	<b>0</b>	0	0
Oil Age	hrs Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>15	<b>0</b>	0	0
Chromium ppm ASTM D5185m	>4	<b>0</b>	0	0
Nickel ppm ASTM D5185m	>2	<b>0</b>	0	0
Titanium ppm ASTM D5185m		<b>0</b>	0	0
Silver ppm ASTM D5185m		<b>0</b>	<1	0
Aluminum ppm ASTM D5185m	>10	<b>0</b>	0	0
Lead ppm ASTM D5185m		<b>0</b>	0	0
Copper ppm ASTM D5185m	>5	<b>25</b>	23	23
Tin ppm ASTM D5185m	>5	<b>&lt;1</b>	<1	<1
Vanadium ppm ASTM D5185m		<b>0</b>	0	0
Cadmium ppm ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		<b>0</b>	0	0
Barium ppm ASTM D5185m		<b>0</b>	<1	0
Molybdenum ppm ASTM D5185m		<b>0</b>	0	0
Manganese ppm ASTM D5185m		<b>0</b>	<1	<1
Magnesium ppm ASTM D5185m		<b>0</b>	0	6
Calcium ppm ASTM D5185m		<b>0</b>	1	2
Phosphorus ppm ASTM D5185m		<b>16</b>	0	<1
Zinc ppm ASTM D5185m		<b>0</b>	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	<b>2</b>	2	2
Sodium ppm ASTM D5185m		<b>0</b>	<1	3
Potassium ppm ASTM D5185m	>20	<b>0</b>	0	0
Water % ASTM D6304	>0.03	<b>0.003</b>	0.004	0.007
ppm Water ppm ASTM D6304	>300	<b>39</b>	44	76.8






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm ASTM D7647		<b>552</b>	149	287
Particles >6µm ASTM D7647	>1300	<b>99</b>	59	107
Particles >14µm ASTM D7647	>160	<b>15</b>	11	12
Particles >21µm ASTM D7647	>40	<b>4</b>	4	4
Particles >38µm ASTM D7647	>10	<b>0</b>	0	0
Particles >71µm ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness ISO 4406 (c)	>--/17/14	<b>16/14/11</b>	14/13/11	15/14/11

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045		<b>0.39</b>	0.37	0.36


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32	36.5	31.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0040980 **Received** : 10 Apr 2024  
**Lab Number** : 06144242 **Tested** : 11 Apr 2024  
**Unique Number** : 10969050 **Diagnosed** : 12 Apr 2024 - Angela Borella  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**ENTERPRISE PRODUCTS**  
P.O. BOX 573  
MONT BELVIEU, TX  
US 77580  
Contact: TOMMY EDWARDS  
tedwards@eprod.com  
T: (281)217-1411  
F: (281)385-4327

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)