


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7451207

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013045	KCP46251	KCP37013
Sample Date		Client Info		27 Mar 2024	23 Feb 2023	30 Aug 2021
Machine Age	hrs	Client Info		5689	4119	1082
Oil Age	hrs	Client Info		1539	3037	917
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	1	3	1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	<1	2	7
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	46	64	72
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		<1	<1	4
Zinc	ppm	ASTM D5185m		0	3	2
Sulfur	ppm	ASTM D5185m		20539	20386	17472
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		11	15	10
Potassium	ppm	ASTM D5185m	>20	0	2	4
Water	%	ASTM D6304	>0.05	<u> </u>	0.025	0.036
ppm Water	ppm	ASTM D6304	>500	△ 3790	253.0	363.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1947	2052	34275
Particles >6µm		ASTM D7647	>1300	393	793	<u>12744</u>
Particles >14µm		ASTM D7647	>80	27	42	4 09
Particles >21µm		ASTM D7647	>20	8	5	△ 96
Particles >38µm		ASTM D7647	>4	0	0	<u>^</u> 6
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	18/17/13	△ 21/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: KCPA013045 : 06144259

Unique Number: 10969067

Lab Number

Tested Diagnosed

Received

: 10 Apr 2024

: 16 Apr 2024

: 16 Apr 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

AMAZON FTW 7 AND 9 944 W SANDY LAKE RD

COPPELL, TX US 75019

Contact: Service Manager

T: F: