




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER AIRCENTER 7.5 5949381 (S/N 1543)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA016199</b>	KCP55816	KCP41000
Sample Date	Client Info		<b>21 Mar 2024</b>	06 Mar 2023	30 Jun 2022
Machine Age	hrs	Client Info	<b>3030</b>	2758	2464
Oil Age	hrs	Client Info	<b>272</b>	300	330
Oil Changed	Client Info		<b>Changed</b>	Not Changd	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 90	<b>0</b>	0	4
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 90	<b>23</b>	38	51
Calcium	ppm	ASTM D5185m 2	<b>0</b>	0	2
Phosphorus	ppm	ASTM D5185m	<b>0</b>	<1	12
Zinc	ppm	ASTM D5185m	<b>28</b>	32	21
Sulfur	ppm	ASTM D5185m	<b>21227</b>	21493	21216

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	1	<1
Sodium	ppm	ASTM D5185m	<b>9</b>	10	18
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	2
Water	%	ASTM D6304 >0.05	<b>▲ 0.331</b>	▲ 0.172	0.007
ppm Water	ppm	ASTM D6304 >500	<b>▲ 3310</b>	▲ 1720	73.3






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>694</b>	1679	9392
Particles >6µm	ASTM D7647 >1300		<b>166</b>	915	▲ 3798
Particles >14µm	ASTM D7647 >80		<b>19</b>	● 156	▲ 91
Particles >21µm	ASTM D7647 >20		<b>5</b>	● 52	6
Particles >38µm	ASTM D7647 >4		<b>0</b>	● 8	0
Particles >71µm	ASTM D7647 >3		<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>17/15/11</b>	● 18/17/14	▲ 20/19/14

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.28</b>	0.34	0.33

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		1.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	45.2	44.8	44.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA016199 **Received** : 10 Apr 2024  
**Lab Number** : 06144265 **Tested** : 16 Apr 2024  
**Unique Number** : 10969073 **Diagnosed** : 16 Apr 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**THERMO FISHER SCIENTIFIC**  
 1321 PLANO RD  
 RICHARDSON, TX  
 US 75081  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)