


OIL ANALYSIS REPORT

ALL ADVANTAGE 46 SE2516L140005 - HAWK TECH

Component Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|----------|-------------|------------|-------------|-------------|-------------|
| Sample Number | | Client Info | | UCH06144398 | UCH05983759 | UCH05792172 |
| Sample Date | | Client Info | | 26 Mar 2024 | 10 Oct 2023 | 01 Mar 2023 |
| Machine Age | hrs | Client Info | | 17895 | 16679 | 15040 |
| Oil Age | hrs | Client Info | | 2900 | 3000 | 2000 |
| Oil Changed | | Client Info | | Not Changd | Not Changd | Changed |
| Sample Status | | | | NORMAL | NORMAL | NORMAL |
| CONTAMINATION | | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | NEG | NEG |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 1 | 0 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >25 | 2 | <1 | 1 |
| Lead | ppm | ASTM D5185m | >25 | <1 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185m | >15 | 1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 15 | 0 | 2 |
| Molybdenum | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Calcium | ppm | ASTM D5185m | | 4 | 0 | 1 |
| Phosphorus | ppm | ASTM D5185m | | 309 | 222 | 219 |
| Zinc | ppm | ASTM D5185m | | 58 | 16 | 41 |
| Sulfur | ppm | ASTM D5185m | | 263 | 274 | 238 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 4 | 5 | 7 |
| Sodium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | <1 | <1 | <1 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.35 | 0.19 | 0.20 |




OIL ANALYSIS REPORT





| VISUAL | | method | limit/base | current | history1 | history2 |
|-------------------------|--------|-----------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| FLUID PROPERT | TIES | method | limit/base | current | history1 | history2 |
| Visc @ 40°C | cSt | ASTM D445 | | 45.2 | 45.3 | 45.6 |


Color





SAMPLE IMAGES


















Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06144398

: UCH06144398 Unique Number : 10969206

Received **Tested**

: 11 Apr 2024 Diagnosed : 12 Apr 2024 - Sean Felton

: 10 Apr 2024

US 61265 Contact: KEVIN DESPOT kevind@a-l-lequipment.com

A-L-L EQUIPMENT INC

204 38TH ST

MOLINE, IL

T: (815)877-7000 F: (309)762-9950

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: KEVIN DESPOT - UCALLMOL