


OIL ANALYSIS REPORT

ALL ADVANTAGE
Machine Id ADVANTAGE
K751912809U - BERRY GLOBAL

Component Compressor



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06144409		
Sample Date		Client Info		01 Apr 2024		
Machine Age	hrs	Client Info		21759		
Oil Age	hrs	Client Info		3650		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	8		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	2		
Copper	ppm	ASTM D5185m	>50	23		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		342		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		18		
Phosphorus	ppm	ASTM D5185m		10		
Zinc	ppm	ASTM D5185m		284		
Sulfur	ppm	ASTM D5185m		215		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m		20		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.45		




OIL ANALYSIS REPORT




VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		45.3		
SAMPLE IMAGES	3	method	limit/base	current	history1	history2


Color	no image	no image
Bottom	no image	no image
ODABUO		

GRAPHS



seesesses lead	
10	
10 +	
5+ :	









Laboratory Sample No.

Lab Number : 06144409

: UCH06144409 Unique Number : 10969217

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 Apr 2024 Tested Diagnosed

: 11 Apr 2024

: 12 Apr 2024 - Sean Felton

A-L-L EQUIPMENT INC 204 38TH ST MOLINE, IL

US 61265 Contact: KEVIN DESPOT kevind@a-l-lequipment.com

T: (815)877-7000 F: (309)762-9950

Test Package : IND 2 Certificate 12367

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)