


OIL ANALYSIS REPORT

PALEXTRA 44 **SULLAIR 003-130658 - SUNRICH**

Component Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCS06144420	UCS06095748	UCS06056814
Sample Date		Client Info		02 Apr 2024	15 Feb 2024	20 Dec 2023
Machine Age	hrs	Client Info		48865	48857	48839
Oil Age	hrs	Client Info		29	25	122
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	2	<1	<1
Tin	ppm	ASTM D5185m	>15	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0.3	<1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0.3	<1	0	0
Magnesium	ppm	ASTM D5185m	0.4	2	0	0
Calcium	ppm	ASTM D5185m	0	<1	0	1
Phosphorus	ppm	ASTM D5185m	689	482	432	462
Zinc	ppm	ASTM D5185m	0	0	0	21
Sulfur	ppm	ASTM D5185m	1237	1183	756	885
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	4	1
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	2	0	0
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.135	0.25	0.24	0.23

Sullivan

42 40

OIL ANALYSIS REPORT



VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
		ام مالم مما	Proc 24 /lean and		hintom d	histom (O


T LOID T HOT LITTIES							
Visc @ 40°C	cSt	ASTM D445	44.62	43.2	43.4	43.4	


SAMPLE IMAGES


Color


Bottom















Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCS06144420

Lab Number : 06144420 Unique Number : 10969228 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received : 10 Apr 2024 **Tested**

: 16 Apr 2024

Diagnosed

: 16 Apr 2024 - Don Baldridge

US 58078 Contact: DALE K dalek@jemco-maxair.com

JEMCO-MAXAIR

WEST FARGO, ND

T: (701)281-0362

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCJEMWES [WUSCAR] 06144420 (Generated: 04/16/2024 10:12:40) Rev: 1

Contact/Location: DALE K - UCJEMWES

F: x: