

OIL ANALYSIS REPORT

Area **ULTRA FG [OIL-46049] INGERSOLL RAND NL1226U14079 - GILSTER MARY LEE-CHESTER CAKE**

Component Compressor

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




Sample Rating Trend




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06144438	UCH06007049	
Sample Date		Client Info		28 Mar 2024	08 Nov 2023	
Machine Age	hrs	Client Info		11568	11096	
Oil Age	hrs	Client Info		472	565	
Oil Changed		Client Info		Not Changd	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		<1	<1	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	2	1	
Lead	ppm	ASTM D5185m	>25	<1	0	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>15	1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		12	10	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		<1	3	
Calcium	ppm	ASTM D5185m		61	57	
Phosphorus	ppm	ASTM D5185m		431	408	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		692	635	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		9	11	
Potassium	ppm	ASTM D5185m	>20	1	2	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.21	0.16	



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	50.5	49.7	
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
		mothod		canon		
Color						no image
Bottom						no image
GRAPHS						
Ferrous Alloys						
2 0 8 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7 8 7			Mar28,24			
≝ Non-ferrous Meta	als		Ma			
Copper s copper lead tin copper tin tin copper tin tin tin tin tin tin tin tin			Mar28/24			
Viscosity @ 40°C			×	Acid Numbe	er	
60 - Abnormal			[©] 0.25			
55			HO 0.20			
50			0.25 0.20 0.20 0.00 0.015 0.00 0.00 0.00 0.00 0.00			
15			E 0.10			
40 Abnormal						
Nov8/23			Mar28/24	Nav8/23		Mar28/24 -
[∠] WearCheck USA - 50 JCH06144438	01 Madisc Rece i	i ved : 10	, NC 27513) Apr 2024		HN HENRY FOSTE 4700 LEBOUR	R COMPANY
6144438	Teste		Apr 2024		SAIN	T LOUIS, MC
10969246	Diagr	nosed : 12	Apr 2024 - Se			US 63134
ND 2 ontact Customer Ser	vice at 1-8	800-237-1369	Э.		Contact: RACHEL \ rvonha	/ON HATTEN atten@jhf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCJOHSAI [WUSCAR] 06144438 (Generated: 04/12/2024 14:40:03) Rev: 1

Certificate L2367

Laboratory

Sample No. Lab Number Unique Number Test Package

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

Page 2 of 2

T: (314)593-1267

F: (314)874-0965