

# **OIL ANALYSIS REPORT**



# **DIAMOND BLUE 8K KAESER 1007 - CSC MISSOURI**

Component Compressor

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		JHF0000099		
Sample Date		Client Info		02 Apr 2024		
Machine Age	hrs	Client Info		37403		
Oil Age	hrs	Client Info		2158		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	V	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	7		
Tin	ppm	ASTM D5185m	>10	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		37		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		5		
Calcium	ppm	ASTM D5185m		4		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		7		
Sulfur	ppm	ASTM D5185m		8479		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	9		
Sodium	ppm	ASTM D5185m		21		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42		




## **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		44.7		


SAMPLE IMAGES	method	limit/base	history1	history2
Color			no image	no image
Bottom			no image	no image

#### **GRAPHS**













Certificate 12367

Laboratory Sample No.

Lab Number : 06144454 Unique Number : 10969262

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : JHF0000099

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Test Package : IND 2

Received : 10 Apr 2024 **Tested** : 11 Apr 2024 Diagnosed

: 12 Apr 2024 - Sean Felton

JOHN HENRY FOSTER COMPANY

4700 LEBOURGET STREET SAINT LOUIS, MO

US 63134

T: (314)593-1267

F: (314)874-0965

Contact: RACHEL VON HATTEN rvonhatten@jhf.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)