




OIL ANALYSIS REPORT



Machine Id
Grand River CAT 1 GRRM01BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (90 GAL)

Sample Rating Trend



NORMAL



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0724924	WC0724872	WC0724910
Sample Date	Client Info		08 Apr 2024	27 Mar 2024	09 Jan 2024
Machine Age	hrs	Client Info	72196	71983	71750
Oil Age	hrs	Client Info	1063	810	617
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>.11	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	3	3	0
Chromium	ppm	ASTM D5185m >4	<1	0	0
Nickel	ppm	ASTM D5185m	<1	<1	1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >6	2	1	2
Lead	ppm	ASTM D5185m >9	2	<1	<1
Copper	ppm	ASTM D5185m >6	2	2	1
Tin	ppm	ASTM D5185m >4	2	0	0
Vanadium	ppm	ASTM D5185m	<1	0	<1
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	2	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	3	3	2
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	11	14	37
Calcium	ppm	ASTM D5185m	1976	1941	1742
Phosphorus	ppm	ASTM D5185m	313	278	266
Zinc	ppm	ASTM D5185m	370	343	339
Sulfur	ppm	ASTM D5185m	2124	2131	1685

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	43	32	22
Sodium	ppm	ASTM D5185m >21	1	1	0
Potassium	ppm	ASTM D5185m >20	2	0	0

INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624	7.7	7.5	7.0
Sulfation	Abs/.1mm	*ASTM D7415	17.9	17.3	16.7

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	14.5	13.6	12.0
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	1.60	2.13	0.89
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	3.86	4.62	4.76











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.8	13.7

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0724924 **Received** : 10 Apr 2024
Lab Number : **06144483** **Tested** : 11 Apr 2024
Unique Number : 10969291 **Diagnosed** : 12 Apr 2024 - Sean Felton
Test Package : MOB 2

EDL NA Recips-Grand River
 Grand River Powerstation, 8550 West Grand River Hwy
 Grand Ledge, MI
 US 48837
 Contact: JAMES ALEXANDER
 james.alexander@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)