




OIL ANALYSIS REPORT



Machine Id
ZOKM02BE (S/N GZJ00540)
 Component
Biogas Engine
 Fluid
SHELL MYSELLA S5 S (160 GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The tin level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0775187	WC0775207	WC0775206
Sample Date	Client Info		05 Apr 2024	19 Mar 2024	11 Mar 2024
Machine Age	hrs	Client Info	83555	83177	82287
Oil Age	hrs	Client Info	162	627	425
Oil Changed	Client Info		Changed	Not Changd	Changed
Sample Status			ABNORMAL	SEVERE	SEVERE

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method		NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	3	9	7
Chromium	ppm	ASTM D5185m >3	<1	<1	<1
Nickel	ppm	ASTM D5185m	<1	<1	<1
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	0	<1	0
Aluminum	ppm	ASTM D5185m >5	3	3	3
Lead	ppm	ASTM D5185m >8	1	2	1
Copper	ppm	ASTM D5185m >5	1	4	3
Tin	ppm	ASTM D5185m >3	▲ 3	5	4
Vanadium	ppm	ASTM D5185m	<1	<1	<1
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	3	4
Barium	ppm	ASTM D5185m	0	1	1
Molybdenum	ppm	ASTM D5185m	4	7	7
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	19	28	27
Calcium	ppm	ASTM D5185m	1640	1628	1582
Phosphorus	ppm	ASTM D5185m 300	359	333	326
Zinc	ppm	ASTM D5185m	436	439	416
Sulfur	ppm	ASTM D5185m	4026	4204	3950

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	140	▲ 282	▲ 226
Sodium	ppm	ASTM D5185m >20	<1	2	<1
Potassium	ppm	ASTM D5185m >20	1	3	2

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	3.9	4.2	4.1
Sulfation	Abs/.1mm	*ASTM D7415	20.7	23.2	21.9


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	12.5	14.4	13.2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.10	1.99	1.58
Base Number (BN)	mg KOH/g	ASTM D2896 5.3	3.25	2.76	3.48




OIL ANALYSIS REPORT


▲ Non-ferrous Metals




FT-IR (Direct Trend)




Acid Number



Base Number











Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.3	13.3

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0775187
Lab Number : 06144487
Unique Number : 10969295
Test Package : MOB 2

Received : 10 Apr 2024
Tested : 11 Apr 2024
Diagnosed : 12 Apr 2024 - Sean Felton

EDL NA Recips-Zook
 Zook Powerstation, 388 E. Main Street
 Leola, PA
 US 17540-1925
 Contact: Kevin Johnson
 kevin.johnson@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: