

COOLANT REPORT

Sample Rating Trend



Machine Id

3A SHREVEPORT

Component Coolant Fluid

{not provided} (--- GAL)

DIAGNOSIS

Recommendation The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition


Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0911499	WC0911504	
Sample Date		Client Info		27 Mar 2024	26 Mar 2024	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.083	1.066	
pН	Scale 0-14	ASTM D1287		7.59	8.74	
Nitrites	ppm	AP-053:2009		1088	676	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		63.1	48.9	
Freezing Point	°F	ASTM D3321		-62	-31	
Total Dissolved Solids				353.5	264.0	
Carboxylate				n/a	n/a	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Pink	Yllow	
Coolant Appearance		*Visual	Clear	normal	normal	
Color						no image






COOLANT REPORT



Iron/Tin/Silver Reserve Alkalinity 14 12 • tin 13 10 q 10 Reserve Alkalinity maa Mar27/24 Copper/Aluminum/Lead Freeze Point 10 10 -10 -20 nt (°C) -30 mdo a -40 -50 -60 -7(-80 Mar27/24 Mar26/24 Nitrites pН 14 3000 Abn 13 2800 12 2600 2400 10 2200 2000 ន្ល 1800 핍 1600 1400 1200 1000 800 600 400 Mar27/24 -Mar27/24 Mar26/24 Mar26 NATIONAL POWER CORP 4541 PRESLYN DR Received : 10 Apr 2024 RALEIGH, NC



Contact/Location: BRANDON RICE - NATRAL Page 2 of 2