


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id

SMALL LOG LINE PECK-COCK

Hydraulic System

ESSO NUTO H ISO 46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec	2023	Jan 2024 Mar 20	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		Y2K0001662	Y2K0001660	Y2K0000191
Sample Date		Client Info		15 Mar 2024	26 Jan 2024	08 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1113	Client Info		N/A	Not Changd	N/A
Sample Status		Oliciti IIIIo		NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	0	0
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	2	2
Lead	ppm	ASTM D5185m	>20	0	1	0
Copper	ppm		>20	1	4	2
Tin	ppm	ASTM D5185m	>20	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	13	6
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	5	0	<1	<1
Calcium	ppm	ASTM D5185m	50	49	51	49
Phosphorus	ppm	ASTM D5185m	330	323	348	368
Zinc	ppm	ASTM D5185m	410	406	429	432
Sulfur	ppm	ASTM D5185m	2700	945	920	935
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.05	0.003	0.006	0.003
ppm Water	ppm	ASTM D6304	>500	36	68	31
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	279	241	60
Particles >6µm		ASTM D7647	>1300	59	96	28
Particles >14μm		ASTM D7647	>160	7	12	5
Particles >21µm		ASTM D7647	>40	2	2	1
Particles >38µm		ASTM D7647	>10	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	15/13/10	15/14/11	13/12/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.45	0.27	0.23	0.24



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number: 10975947

: Y2K0001662 : 06145869

Received : 11 Apr 2024 **Tested** Diagnosed

: 12 Apr 2024

: 12 Apr 2024 - Wes Davis Test Package : MOB 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

INDUSTRIAL POWER SYSTEMS

5151 OLD SALEM RD ALBANY, OR US 97322

Contact: CURTIS STECKLER curtis@ipowersystems.com T: (503)560-2593

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: INDALB [WUSCAR] 06145869 (Generated: 04/12/2024 10:39:22) Rev: 1

Contact/Location: CURTIS STECKLER - INDALB