

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8453627

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC122401		
Sample Date		Client Info		28 Mar 2024		
Machine Age	hrs	Client Info		47		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver		ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
	ppm					
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m		0		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	39		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	77		
Calcium	ppm	ASTM D5185m	2	6		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		9		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304	>0.05	0.020		
ppm Water	ppm	ASTM D6304	>500	201		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16130		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	A 218		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
		ASTM D8045				
Acid Number (AN)	mg KOH/g	A311VI D0043	0.4	0.37		



OIL ANALYSIS REPORT

20k ·	Particle Trend		VISUAL		method	limit/base	current	history1	history2
(4μm		White Metal	scalar	*Visual	NONE	NONE		
number of particles (1 ml) 92 ml			Yellow Metal	scalar	*Visual	NONE	NONE		
ing 10k ·			Precipitate	scalar	*Visual	NONE	NONE		
oer of j			Silt	scalar	*Visual	NONE	NONE		
June 5k ·			Debris	scalar	*Visual	NONE	NONE		
0k ·			Sand/Dirt	scalar	*Visual	NONE	NONE		
	Mar28/24	Mar28/24	Appearance	scalar	*Visual	NORML	NORML		
	Mar	Mari	Odor	scalar	*Visual	NORML	NORML		
•	Water (KF)		Emulsified Water	scalar	*Visual	>0.05	NEG		
12000	1		Free Water	scalar	*Visual		NEG		
10000	Severe	-	FLUID PROPER	TIES	method	limit/base	current	history1	history2
8000·			Visc @ 40°C	cSt	ASTM D445	46	43.2		
6000 4000			SAMPLE IMAGE	S	method	limit/base	current	history1	history2
2000	Abnormal								
U.	Mar28/24	Mar28/24	Color					no image	no image
0.50	Acid Number		Bottom				a	no image	no image
0.40 0.30	Base								
0.30			GRAPHS						
0.20			Ferrous Alloys				Particle Count		
0.10			10 iron			491,520	1		126
0.00	4		6 - needed chromium			122,880	-		-24
	Mar28/24	20				30,720			-22
	M	44	2			30,720			T22
	Water (KF)		0			7,680			-20
2000.	Severe		Mar28,24			Mar28/24 s (per 1 ml			110
0000.	- G					<u>a</u>			-21 -18 -14 -14
8000.			Non-ferrous Meta	ls		offred 480		/	-16
6000·			8 - copper			jo 120	-		-14
4000.			= 6 + minimum tin			lag 120			
2000.	Abnormal					30			+L
0.	24	ς. Σ	2				Bioreve mal		-1
	Mar28/24	8 C~11				t. 2	I		
		-	Mar28/24			Mar28/24			
52.	Viscosity @ 40°C		≥ Viscosity @ 40°C			≥ 0	μ 6μ	14µ 21µ	38µ 71µ
50-	Abnormal		⁵⁵ T			- 0.50	Acid Number		
48			50 Abnormal			(BHO) 0.40	Base		*****
46	Base -		Base 45 45 Abnormal			E 0 30			
5 44.			る が Abnormal			4 0.20 MmN 0.10 V 0.00	-		
42.	Abnormal		40 -			N 0.10			
40· 38·			35				4		
50	8/24	P.C.O	Mar28/24			Mar28/24	Mar28/24		
	Mar28/24	h and	2			N	Z		
		Sample No. Lab Number Unique Number	: 10975960	Rece Teste	ived :11 ed :12	v, NC 27513 1 Apr 2024 2 Apr 2024 Apr 2024 - Don	Baldridge	250 MILL ST,	TAYLORS, S US 296
	Certificate L2367	Test Package						Contact: Se	ervice Manag
			: IND 2 contact Customer Serv	vice at 1-8	800-237-136	9.		Contact: So	ervice Manag

Report Id: STOTAY [WUSCAR] 06145882 (Generated: 04/15/2024 18:53:41) Rev: 1

Contact/Location: Service Manager - STOTAY Page 2 of 2