


OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id **3211571**

Component Compressor

TULCO LUBSOIL LPG WI 100 (120 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		3y2016 Aug21	016 Feb2017 Dec2017	Oct2018 Jan2020 Aug2023	Feb 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90002441	TO90002443	TO90002445
Sample Date		Client Info		01 Apr 2024	01 Mar 2024	01 Feb 2024
Machine Age	hrs	Client Info		66148	67621	66765
Oil Age	hrs	Client Info		0	0	168
Oil Changed		Client Info		Filtered	Filtered	Filtered
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>25	0	<1	<1
Copper	ppm	ASTM D5185m	>50	0	0	0
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	1	2
Calcium	ppm	ASTM D5185m		<1	<1	2
Phosphorus	ppm	ASTM D5185m	0	0	<1	0
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	1158	1280	867
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	15	<u>^</u> 26	14
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	3	3
Water	%	ASTM D6304	>2.26	0.358	0.329	0.304
ppm Water	ppm	ASTM D6304	>22600	3585	3296	3048
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	10278	17276	17423
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>4297</u>	△ 3076
Particles >14µm		ASTM D7647	>320	78	183	77
Particles >21µm		ASTM D7647	>80	22	32	17
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/15	21/18/13	△ 21/19/15	<u>\$\rightarrow\$ 21/19/13</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.11	1.23	1.16



OIL ANALYSIS REPORT







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : TO90002441 Lab Number : 06145944 Unique Number : 10976022

Received **Tested** Diagnosed

: 15 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

: 11 Apr 2024

: 12 Apr 2024

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. **MORROW RENEWABLES** 8601 N JASMAN RD

EDINBURG, TX US 78539

Contact: JESUS CASAREZ icasarez@morrowrenew.com

T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: MOREDI [WUSCAR] 06145944 (Generated: 04/15/2024 11:58:14) Rev: 1

Contact/Location: JESUS CASAREZ - MOREDI

F: