

PROBLEM SUMMARY

Sample Rating Trend



Machine Id

JAX-P258 Component Pump Fluid {not provided} (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ABNORMAL				
Water	%	ASTM D6304	>.1	0.673	0.099				
ppm Water	ppm	ASTM D6304	>1000	6730	990				
Emulsified Water	scalar	*Visual	>.1	0.2%	0.1%				
Free Water	scalar	*Visual		▲ >10%	NEG				

Customer Id: RENJAC Sample No.: RP06145956 Lab Number: 06145956 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Check Water Access			?	We advise that you check for the source of water entry.			

HISTORICAL DIAGNOSIS



15 Apr 2009 Diag: Doug Bogart No corrective action is recommended at this time. We recommend an early resample to monitor this condition. The iron level is abnormal. Moderate concentration of visible dirt/debris present in the oil. The condition of oil is suitable for further service.





OIL ANALYSIS REPORT



Machine Id

JAX-P258 Component Pump Fluid {not provided} (--- GAL)

DIAGNOSIS

A Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM		method	iimit/base	current	nistory i	nistory2
Sample Number		Client Info		RP06145956	RP61412	
Sample Date		Client Info		11 Mar 2024	15 Apr 2009	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				SEVERE	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	2	6 5	
Chromium	ppm	ASTM D5185m	>5	<1	2	
Nickel	ppm	ASTM D5185m	>5	1	2	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>3	<1	<1	
Aluminum	ppm	ASTM D5185m	>7	1	0	
Lead	ppm	ASTM D5185m	>12	2	6	
Copper	ppm	ASTM D5185m	>30	14	6	
Tin	ppm	ASTM D5185m	>9	1	<1	
Antimony	ppm	ASTM D5185m			4	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	
Barium	ppm	ASTM D5185m		<1	3	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	1	
Magnesium	ppm	ASTM D5185m		6	48	
Calcium	ppm	ASTM D5185m		3	4	
Phosphorus	ppm	ASTM D5185m		4	24	
Zinc	ppm	ASTM D5185m		3	16	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	10	0	
Sodium	ppm	ASTM D5185m		0	1	
Potassium	ppm	ASTM D5185m	>20	<1	0	
Water	%	ASTM D6304	>.1	0.673	0.099	
ppm Water	ppm	ASTM D6304	>1000	6730	990	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42	0.476	



OIL ANALYSIS REPORT







VISUAL history1 NONE NONE LIGHT White Metal *Visual scalar Yellow Metal *Visual NONE NONE NONE scalar NONE Precipitate scalar *Visua NONE NONE Silt scalar *Visual NONE NONE NONE Debris *Visual NONE NONE MODER scalar Sand/Dirt NONE NONE scalar *Visual NONE NORML Appearance scalar *Visual NORML NORML Odor *Visual NORML NORML scalar NORML **Emulsified Water** scalar *Visual >.1 **0.2%** 0.1% Free Water scalar *Visual **A** >10% NEG **FLUID PROPERTIES** limit/base history Visc @ 40°C cSt ASTM D445 67.0 65.21 SAMPLE IMAGES Color no image no image Bottom no image no imade GRAPHS Ferrous Alloys 20 1 Non-ferrous Metals Mar11/24 Viscosity @ 40°C Acid Number (^{0.50} (⁰/HOX) 0.40 () 50 Ē 0.30 40. · 문 0.20 30 Abnorma 0.10 Acid 20 0.00 Mar11/24 -Apr15/09 1/24 Marl : WearCheck USA - 501 Madison Ave., Cary, NC 27513 SYMRISE : RP06145956 Received : 11 Apr 2024 601 CRESTWOOD ST Lab Number : 06145956 JACKSONVILLE, FL Tested : 15 Apr 2024 Unique Number : 10976034 Diagnosed : 15 Apr 2024 - Don Baldridge US 32208 Test Package : IND 2 Contact: ADAM BOVITCH ADAM.BOVITCH@SYMRISE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

80 60

Ē.40

70

60

ŝ

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: RENJAC [WUSCAR] 06145956 (Generated: 04/15/2024 12:03:07) Rev: 1

Certificate 12367

Laboratory

Sample No.

Contact/Location: ADAM BOVITCH - RENJAC

E:

T: (904)924-2765