




OIL ANALYSIS REPORT

Sample Rating Trend



Area
BEEBE [2000060080]
 Machine Id
54WEA82670 (S/N 72802120545)
 Component
Wind Turbine Gearbox
 Fluid
CASTROL OPTIGEAR SYNTHETIC X 320 (--- LTR)

DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
 The aluminum level is abnormal. All other component wear rates are normal.

Contamination
 There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			NX013786	NX06067701	NX06067693
Sample Date	Client Info			09 Apr 2024	21 Jan 2024	02 Nov 2023
Machine Age	hrs	Client Info		68051	0	78378
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				ABNORMAL	SEVERE	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>80	21	▲ 187	28
Iron	ppm	ASTM D5185m	>150	72	▲ 489	59
Chromium	ppm	ASTM D5185m	>5	1	4	<1
Nickel	ppm	ASTM D5185m	>10	1	3	1
Titanium	ppm	ASTM D5185m	>10	<1	<1	<1
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>10	▲ 12	4	5
Lead	ppm	ASTM D5185m	>20	<1	<1	<1
Copper	ppm	ASTM D5185m	>50	1	2	1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		1	<1	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		6	4	5
Molybdenum	ppm	ASTM D5185m	1150	1392	715	876
Manganese	ppm	ASTM D5185m		2	5	1
Magnesium	ppm	ASTM D5185m		12	21	8
Calcium	ppm	ASTM D5185m	2000	2590	1618	1727
Phosphorus	ppm	ASTM D5185m	400	500	373	380
Zinc	ppm	ASTM D5185m	0	3	2	0
Sulfur	ppm	ASTM D5185m	1850	2875	2104	2321

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	21	15	15
Sodium	ppm	ASTM D5185m	>20	3	5	0
Potassium	ppm	ASTM D5185m	>20	2	2	1
Water	%	ASTM D6304	>0.05	0.00	0.036	0.021
ppm Water	ppm	ASTM D6304	>500	0	369	216


FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		41030	766	16810
Particles >6µm		ASTM D7647	>2500	1182	117	764
Particles >14µm		ASTM D7647	>320	6	12	11
Particles >21µm		ASTM D7647	>80	2	5	4
Particles >38µm		ASTM D7647	>20	0	2	1
Particles >71µm		ASTM D7647	>4	0	1	1
Oil Cleanliness		ISO 4406 (c)	>--/18/15	23/17/10	17/14/11	21/17/11

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.6	0.98	0.519	1.06




OIL ANALYSIS REPORT


▲ Aluminum (ppm)




Water (KF)




PQ



Particle Trend




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	314	320

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : NX013786

Lab Number : 06146572

Unique Number : 10976650

Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 11 Apr 2024

Tested : 12 Apr 2024

Diagnosed : 16 Apr 2024 - Jonathan Hester

NORDEX USA - BEEBE

1200 S COUNTY FARM RD

ITHACA, MI

US 48847

Contact: TUCKER WITT

tucker.witt@constellation.com

T:

F: (312)386-7102