




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
BEEBE [2000060080]

Machine Id
05WEA82341

Component
Wind Turbine Gearbox

Fluid
CASTROL OPTIGEAR SYNTHETIC X 320 (4 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		NX06146578	NX05798675	NX005621
Sample Date	Client Info		29 Feb 2024	02 Feb 2023	05 Aug 2021
Machine Age	hrs	Client Info	96940	72393	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>80	27	▲ 169	▲ 161	
Iron	ppm	ASTM D5185m	>150	63	▲ 596	▲ 437
Chromium	ppm	ASTM D5185m	>5	1	▲ 6	5
Nickel	ppm	ASTM D5185m	>10	1	3	2
Titanium	ppm	ASTM D5185m	>10	<1	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>10	7	2	0
Lead	ppm	ASTM D5185m	>20	<1	0	<1
Copper	ppm	ASTM D5185m	>50	1	2	1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m	>5	---	---	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		4	2	0
Molybdenum	ppm	ASTM D5185m	1150	929	833	765
Manganese	ppm	ASTM D5185m		1	5	3
Magnesium	ppm	ASTM D5185m		7	16	19
Calcium	ppm	ASTM D5185m	2000	1713	1650	1587
Phosphorus	ppm	ASTM D5185m	400	340	325	333
Zinc	ppm	ASTM D5185m	0	<1	6	4
Sulfur	ppm	ASTM D5185m	1850	1967	1678	1674

CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	14	14	8
Sodium	ppm	ASTM D5185m	>20	0	0	5
Potassium	ppm	ASTM D5185m	>20	1	<1	<1
Water	%	ASTM D6304	>0.05	0.004	0.011	0.043
ppm Water	ppm	ASTM D6304	>500	46	115.7	438.8

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		73120	21672	150697
Particles >6µm	ASTM D7647	>2500	● 3807	● 2545	▲ 31026
Particles >14µm	ASTM D7647	>320	19	33	14
Particles >21µm	ASTM D7647	>80	2	6	2
Particles >38µm	ASTM D7647	>20	0	1	0
Particles >71µm	ASTM D7647	>4	0	1	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	● 23/19/11	● 22/19/12	▲ 24/22/11



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.6	1.06	0.41	0.344






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	320	309	304

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX06146578 **Received** : 11 Apr 2024
Lab Number : **06146578** **Tested** : 12 Apr 2024
Unique Number : 10976656 **Diagnosed** : 15 Apr 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

NORDEX USA - BEEBE
 1200 S COUNTY FARM RD
 ITHACA, MI
 US 48847
 Contact: TUCKER WITT
 tucker.witt@constellation.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)