


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

8687481 (S/N 1228)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

				Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016866		
Sample Date		Client Info		28 Mar 2024		
Machine Age	hrs	Client Info		1172		
Oil Age	hrs	Client Info		1172		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
·		and the sale	11		for the second of	la la La ma O
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>10	3		
Copper	ppm	ASTM D5185m	>50	4		
Tin	ppm	ASTM D5185m	>10	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	58		
Molybdenum	ppm	ASTM D5185m	0	1		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	100	74		
Calcium	ppm	ASTM D5185m	0	8		
Phosphorus	ppm	ASTM D5185m	0	7		
Zinc	ppm	ASTM D5185m	0	9		
Sulfur	ppm	ASTM D5185m	23500	20576		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		15		
Potassium	ppm	ASTM D5185m	>20	13		
Water	%	ASTM D6304	>0.05	0.018		
ppm Water	ppm	ASTM D6304	>500	181		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		159443		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	▲ 3596		
Particles >21µm		ASTM D7647	>20	<u>▲</u> 188		
Particles >38µm		ASTM D7647	>4	6		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	△ 24/24/19		
		. ,				
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.32		



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KCPA016866 Lab Number : 06146593 Unique Number : 10976671

Received : 11 Apr 2024 **Tested** Diagnosed

: 12 Apr 2024 : 15 Apr 2024 - Angela Borella

14 HIGH BRIDGE RD SANDY HOOK, CT Contact: R. PENIOWICH

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: R. PENIOWICH - SMTSAN

rpeniowich@smtcorp.com

US 06482

T:

F: