




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**6597242 (S/N NOT GIVEN)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCA013810</b>	KCPA007545	---
Sample Date	Client Info		<b>04 Apr 2024</b>	10 Oct 2023	---
Machine Age	hrs	Client Info	<b>4420</b>	3598	---
Oil Age	hrs	Client Info	<b>900</b>	0	---
Oil Changed	Client Info		<b>Changed</b>	N/A	---
Sample Status			<b>ABNORMAL</b>	ABNORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>1</b>	0	---
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	---
Nickel	ppm	ASTM D5185m >3	<b>&lt;1</b>	0	---
Titanium	ppm	ASTM D5185m >3	<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m >10	<b>1</b>	0	---
Lead	ppm	ASTM D5185m >10	<b>2</b>	0	---
Copper	ppm	ASTM D5185m >50	<b>2</b>	3	---
Tin	ppm	ASTM D5185m >10	<b>1</b>	0	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	---
Barium	ppm	ASTM D5185m 90	<b>10</b>	0	---
Molybdenum	ppm	ASTM D5185m 0	<b>1</b>	0	---
Manganese	ppm	ASTM D5185m	<b>1</b>	<1	---
Magnesium	ppm	ASTM D5185m 100	<b>56</b>	23	---
Calcium	ppm	ASTM D5185m 0	<b>5</b>	<1	---
Phosphorus	ppm	ASTM D5185m 0	<b>6</b>	4	---
Zinc	ppm	ASTM D5185m 0	<b>21</b>	35	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	<1	---
Sodium	ppm	ASTM D5185m	<b>15</b>	12	---
Potassium	ppm	ASTM D5185m >20	<b>3</b>	<1	---
Water	%	ASTM D6304 >0.05	<b>0.034</b>	▲ 0.174	---
ppm Water	ppm	ASTM D6304 >500	<b>345</b>	▲ 1740	---






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>10230</b>	---	---
Particles >6µm	ASTM D7647	>1300	▲ <b>2709</b>	---	---
Particles >14µm	ASTM D7647	>80	● <b>98</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>16</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>1</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>21/19/14</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.34</b>	0.24	---


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	● HAZY
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	45.0	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCA013810  
**Lab Number** : 06146607  
**Unique Number** : 10976685  
**Test Package** : IND 2  
**Received** : 11 Apr 2024  
**Tested** : 12 Apr 2024  
**Diagnosed** : 16 Apr 2024 - Angela Borella

**ONEIDA WATER TREATMENT**  
 51 LELAND AVENUE  
 UTICA, NY  
 US 13502  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)