




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

KAESER 7354426

Component

Compressor

Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA016894	KCP48184D	KCP52455
Sample Date	Client Info		05 Apr 2024	05 Sep 2023	23 Feb 2023
Machine Age	hrs	Client Info	21247	16735	13857
Oil Age	hrs	Client Info	8000	4000	3000
Oil Changed	Client Info		Changed	Changed	Changed
Sample Status			ABNORMAL	NORMAL	ATTENTION

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	0	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	<1	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	1	0	<1
Lead	ppm	ASTM D5185m >10	1	0	0
Copper	ppm	ASTM D5185m >50	7	<1	<1
Tin	ppm	ASTM D5185m >10	1	<1	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	24	36	45
Molybdenum	ppm	ASTM D5185m 0	1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	1
Magnesium	ppm	ASTM D5185m 100	69	68	102
Calcium	ppm	ASTM D5185m 0	4	1	2
Phosphorus	ppm	ASTM D5185m 0	4	6	<1
Zinc	ppm	ASTM D5185m 0	9	5	26
Sulfur	ppm	ASTM D5185m 23500	20890	23478	24059

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	1	1
Sodium	ppm	ASTM D5185m	13	18	14
Potassium	ppm	ASTM D5185m >20	5	4	7
Water	%	ASTM D6304 >0.05	0.020	0.036	0.018
ppm Water	ppm	ASTM D6304 >500	208	360.7	188.9






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		30387	1573	7494
Particles >6µm	ASTM D7647	>1300	▲ 7689	494	● 2337
Particles >14µm	ASTM D7647	>80	▲ 419	35	● 97
Particles >21µm	ASTM D7647	>20	▲ 88	6	● 22
Particles >38µm	ASTM D7647	>4	2	0	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 22/20/16	18/16/12	● 20/18/14

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.42	0.36	0.39


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	49.1	48.2	47.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA016894 **Received** : 11 Apr 2024
Lab Number : 06146614 **Tested** : 12 Apr 2024
Unique Number : 10976692 **Diagnosed** : 16 Apr 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

AMAZON
 9700 S 13TH ST
 OAK CREEK, WI
 US 53154
 Contact: Service Manager
 ssswosin@amazon.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)