




# OIL ANALYSIS REPORT

Sample Rating Trend



## VISCOSITY



Machine Id  
**KAESER SK20 7347944 (S/N 1618)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- QTS)**

### DIAGNOSIS

#### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### ▲ Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA016121</b>	KCPA001135	KCP44459
Sample Date	Client Info		<b>04 Apr 2024</b>	28 Mar 2023	29 Mar 2022
Machine Age	hrs	Client Info	<b>30309</b>	23005	15594
Oil Age	hrs	Client Info	<b>7304</b>	0	0
Oil Changed	Client Info		<b>Changed</b>	N/A	Not Changd
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	<1	1
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	1	0	<1
Lead	ppm	ASTM D5185m >10	1	0	0
Copper	ppm	ASTM D5185m >50	17	29	12
Tin	ppm	ASTM D5185m >10	1	0	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	<1	0	0
Molybdenum	ppm	ASTM D5185m 0	1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 100	2	3	22
Calcium	ppm	ASTM D5185m 0	5	1	0
Phosphorus	ppm	ASTM D5185m 0	3	4	0
Zinc	ppm	ASTM D5185m 0	1	<1	29
Sulfur	ppm	ASTM D5185m 23500	<b>18233</b>	17644	17254

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	0	<1	<1
Sodium	ppm	ASTM D5185m	0	0	5
Potassium	ppm	ASTM D5185m >20	<1	<1	2
Water	%	ASTM D6304 >0.05	<b>0.007</b>	0.008	0.007
ppm Water	ppm	ASTM D6304 >500	<b>78</b>	84.1	76.1






### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>14000</b>	2825	11100
Particles >6µm	ASTM D7647	>1300	▲ <b>3686</b>	838	▲ 4259
Particles >14µm	ASTM D7647	>80	▲ <b>235</b>	62	▲ 507
Particles >21µm	ASTM D7647	>20	▲ <b>47</b>	15	▲ 71
Particles >38µm	ASTM D7647	>4	<b>3</b>	0	2
Particles >71µm	ASTM D7647	>3	<b>2</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>21/19/15</b>	19/17/13	▲ 19/16

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.47</b>	0.47	0.43


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	▲ 54.9	▲ 61.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA016121 **Received** : 11 Apr 2024  
**Lab Number** : 06146622 **Tested** : 12 Apr 2024  
**Unique Number** : 10976700 **Diagnosed** : 16 Apr 2024 - Angela Borella  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**MCLAIN FARMS INC**  
 534 MCLAIN CEMETERY RD  
 LYONS, GA  
 US 30436  
 Contact: CHRIS  
 CHRIS@MCLAINFARMS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)