




# PROBLEM SUMMARY

Area  
**CANNING**  
 Machine Id  
**SEAM TEAR DROP**  
 Component  
**Gearbox**  
 Fluid  
**LUBRIPLATE SFGO ULTRA 220 (3 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you inspect for the source(s) of wear.  
 We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
PQ		ASTM D8184		▲ 1872	▲ 134	21
Silicon	ppm	ASTM D5185m	>50	▲ 110	4	5
White Metal	scalar	*Visual	NONE	▲ HEAVY	NONE	NONE
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ VHEVY	MODER

Customer Id: PEPTUL  
 Sample No.: TO10003305  
 Lab Number: 06146775  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### WEAR



#### 16 Jan 2024 Diag: Doug Bogart

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Gear wear is indicated. Appearance is unacceptable. There is a high concentration of water present in the oil. There is a high amount of visible silt present in the sample. The oil is no longer serviceable due to the presence of contaminants.

[view report](#)



### WATER



#### 05 Sep 2023 Diag: Jonathan Hester

We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)



### WATER



#### 17 Jul 2023 Diag: Jonathan Hester


We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Excessive free water present. There is a moderate concentration of water present in the oil. The oil is no longer serviceable due to the presence of contaminants.

[view report](#)



# OIL ANALYSIS REPORT

Sample Rating Trend



Area  
**CANNING**  
 Machine Id  
**SEAM TEAR DROP**  
 Component  
**Gearbox**  
 Fluid  
**LUBRIPLATE SFGO ULTRA 220 (3 GAL)**

## DIAGNOSIS

**Recommendation**  
 We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

**Wear**  
 High concentration of visible metal present. The very high ferrous density (PQ) index indicates that severe wear is occurring.

**Contamination**  
 There is a high amount of visible silt present in the sample.

**Fluid Condition**  
 The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO10003305</b>	TO90002188	TO10002549
Sample Date	Client Info		<b>09 Apr 2024</b>	16 Jan 2024	05 Sep 2023
Machine Age	wks	Client Info	<b>0</b>	0	0
Oil Age	wks	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>▲ 1872</b>	▲ 134	21
Iron	ppm	ASTM D5185m >200	<b>2</b>	▲ 474	7
Chromium	ppm	ASTM D5185m >15	<b>0</b>	3	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	2	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>0</b>	1	0
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	2	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	2	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	9	<1
Phosphorus	ppm	ASTM D5185m	<b>102</b>	94	220
Zinc	ppm	ASTM D5185m	<b>0</b>	0	4
Sulfur	ppm	ASTM D5185m	<b>25</b>	32	2557






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>▲ 110</b>	4	5
Sodium	ppm	ASTM D5185m	<b>0</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	7	3
Water	%	ASTM D6304 >0.2	<b>0.085</b>	▲ 1.60	▲ 0.529
ppm Water	ppm	ASTM D6304 >2000	<b>850</b>	▲ 16000	▲ 5290

## VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	<b>▲ HEAVY</b>	NONE	NONE
Yellow Metal	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual NONE	<b>▲ HEAVY</b>	▲ VHEVY	MODER
Debris	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual NORML	<b>NORML</b>	● MILKY	NORML
Odor	scalar	*Visual NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual >0.2	<b>0.2%</b>	▲ 0.2%	0.2%
Free Water	scalar	*Visual	<b>NEG</b>	NEG	NEG






# OIL ANALYSIS REPORT



FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 222	<b>214</b>	209	216
Visc @ 100°C	cSt	ASTM D445 26	<b>25.2</b>	19.8	20.1
Viscosity Index (VI)	Scale	ASTM D2270 146	<b>148</b>	108	<b>▲ 107</b>

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			no image		
Bottom			no image		

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO10003305 **Received** : 11 Apr 2024  
**Lab Number** : **06146775** **Tested** : 18 Apr 2024  
**Unique Number** : 10976853 **Diagnosed** : 18 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, VI )

**PEPSI BOTTLING GROUP**  
 510 W SKELLY DR  
 TULSA, OK  
 US 74107  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)