




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
RRHP Turbine Pit 699 Elevation
 Machine Id
029-200-410 Unit 2 TGB
 Component
Guide Bearing
 Fluid
MOBIL DTE 26 (36 GAL)

DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0927628	WC0879258	---
Sample Date	Client Info		07 Mar 2024	20 Nov 2023	---
Machine Age	hrs	Client Info	7867	7480	---
Oil Age	hrs	Client Info	7867	7480	---
Oil Changed	Client Info		Not Chngd	Filtered	---
Sample Status			NORMAL	NORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	1	0	---
Chromium	ppm	ASTM D5185m >20	<1	0	---
Nickel	ppm	ASTM D5185m >20	<1	0	---
Titanium	ppm	ASTM D5185m	<1	0	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >20	1	0	---
Lead	ppm	ASTM D5185m >20	1	0	---
Copper	ppm	ASTM D5185m >20	1	<1	---
Tin	ppm	ASTM D5185m >20	1	0	---
Vanadium	ppm	ASTM D5185m	<1	0	---
Cadmium	ppm	ASTM D5185m	1	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	---
Barium	ppm	ASTM D5185m	<1	0	---
Molybdenum	ppm	ASTM D5185m	<1	0	---
Manganese	ppm	ASTM D5185m	<1	0	---
Magnesium	ppm	ASTM D5185m	<1	0	---
Calcium	ppm	ASTM D5185m	123	114	---
Phosphorus	ppm	ASTM D5185m	504	458	---
Zinc	ppm	ASTM D5185m	679	654	---
Sulfur	ppm	ASTM D5185m	9059	7838	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	1	<1	---
Sodium	ppm	ASTM D5185m	1	2	---
Potassium	ppm	ASTM D5185m >20	2	0	---
Water	%	ASTM D6304 >2	0.003	0.007	---
ppm Water	ppm	ASTM D6304	37	75	---

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	492	1069	---
Particles >6µm	ASTM D7647	>2500	130	385	---
Particles >14µm	ASTM D7647	>160	12	9	---
Particles >21µm	ASTM D7647	>40	3	2	---
Particles >38µm	ASTM D7647	>10	0	1	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>20/18/14	16/14/11	17/16/10	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.649	0.61	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	71.2	63.0	63.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0927628
Lab Number : 06147330
Unique Number : 10977408
Test Package : PLANT

Missouri River Energy Services - Red Rock Hydro
 1004 216th Place
 Pella, IA
 CA 50219

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: Vern Cochran
 vern.cochran@mrenergy.com
 T: (605)357-6920

F: