


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7492092 (S/N 1172)

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

🛑 Wear

An increase in the iron level is noted. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017088	KC103747	KC90672
Sample Date		Client Info		09 Apr 2024	04 Apr 2022	19 Oct 2021
Machine Age	hrs	Client Info		21336	9247	6237
Oil Age	hrs	Client Info		0	2826	6237
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	36	<1	<1
Chromium	ppm	ASTM D5185m		1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	1	<1	<1
Lead	ppm	ASTM D5185m	>10	1	<1	0
Copper	ppm	ASTM D5185m		7	3	16
Tin	ppm	ASTM D5185m	>10	1	0	0
Antimony	ppm	ASTM D5185m	210			0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES	ppin	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	<1
Barium	ppm	ASTM D5185m	90	<1	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1 0	0 <1
Manganese Magnesium	ppm	ASTM D5185m ASTM D5185m	100	1	30	28
Calcium	ppm	ASTM D5185m		4	0	0
	ppm	ASTM D5185m	0	4	4	0
Phosphorus Zinc	ppm	ASTM D5185m	0	9	4	54
Sulfur	ppm	ASTM D5185m	•	9 19978	10944	16165
	ppm					
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m	00	1	10	32
Potassium	ppm	ASTM D5185m		2	8	32
Water	%	ASTM D6304		0.010	0.012	0.016
ppm Water	ppm	ASTM D6304		107	127.5	162.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	1000	6020	7994	494
Particles >6µm		ASTM D7647		▲ 2398	▲ 3553	169
Particles >14µm		ASTM D7647	>80	▲ 480	▲ 745	14
Particles >21µm		ASTM D7647		▲ 165	<u>▲</u> 261	3
Particles >38µm		ASTM D7647	>4	▲ 6	▲ 11 0	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/18/16	▲ 19/17	15/11
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN) :18:35) Rev: 1	mg KOH/g	ASTM D8045	1.0	0.53 Contact/Locatio	0.37 on: Service Man	0.328 ager - PURNAS

Report Id: PURNAS [WUSCAR] 06147343 (Generated: 04/16/2024 11:18:35) Rev: 1


Contact/Location: Service Manager - PURNAS





Built for a lifetime.



A Particle Tre	nd	
4μm		
E 8k 12 8b 30 6k 14μm 14μm 10 4k 10 4k 12 14μm	NAME AND ADDRESS OF TAXABLE PARTY.	
Jon	Apr4/22 +	Apr8/24








VISUAL method limit/base current

					,	,
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	53.2	50.7	44.6
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						
					U.	

history1

history2



Tested

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed



Abnorma

2000



T: F:

Report Id: PURNAS [WUSCAR] 06147343 (Generated: 04/16/2024 11:18:35) Rev: 1

Certificate 12367

Lab Number : 06147343

Unique Number : 10977421

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact/Location: Service Manager - PURNAS

US 37204