




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER AS 25T 2754092 (S/N 1206)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA013157	KCP26967	KCP17085
Sample Date	Client Info		09 Feb 2024	09 Mar 2020	26 Jul 2019
Machine Age	hrs	Client Info	49994	41682	39943
Oil Age	hrs	Client Info	0	0	1970
Oil Changed	Client Info		Changed	Not Changd	Changed
Sample Status			NORMAL	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	2	0	<1
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	<1	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	<1	<1	0
Aluminum	ppm	ASTM D5185m >10	1	0	0
Lead	ppm	ASTM D5185m >10	1	0	<1
Copper	ppm	ASTM D5185m >50	10	8	7
Tin	ppm	ASTM D5185m >10	1	0	<1
Antimony	ppm	ASTM D5185m	---	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	29	<1
Barium	ppm	ASTM D5185m 90	<1	0	0
Molybdenum	ppm	ASTM D5185m	<1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 90	22	17	2
Calcium	ppm	ASTM D5185m 2	3	<1	<1
Phosphorus	ppm	ASTM D5185m	4	2	<1
Zinc	ppm	ASTM D5185m	54	70	40
Sulfur	ppm	ASTM D5185m	21162	16155	18752

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	0	0	2
Sodium	ppm	ASTM D5185m	8	2	<1
Potassium	ppm	ASTM D5185m >20	2	<1	1
Water	%	ASTM D6304 >0.05	0.016	0.012	0.009
ppm Water	ppm	ASTM D6304 >500	162	120.0	97.6






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		724	1464	13857
Particles >6µm	ASTM D7647	>1300	247	387	▲ 3074
Particles >14µm	ASTM D7647	>80	73	49	▲ 180
Particles >21µm	ASTM D7647	>20	36	17	▲ 74
Particles >38µm	ASTM D7647	>4	5	1	▲ 8
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	17/15/13	16/13	▲ 19/15

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.35	0.327	0.320


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.2	43.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA013157 **Received** : 12 Apr 2024
Lab Number : 06147348 **Tested** : 15 Apr 2024
Unique Number : 10977426 **Diagnosed** : 16 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

QSD MANUFACTURING INC
 5700 MITCHELLDALE ST
 HOUSTON, TX
 US 77092
 Contact: BJ POOLE
 bjpoole@qsdmfg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)