

## **OIL ANALYSIS REPORT**

### Area MELT SHOP - HYDRAULIC MELT SHOP EAF MAIN HYDRAULIC UNIT (S/N 15-2000-0815-0010) Component

Tank Hydraulic System

Fluid FIRE-RESISTANT FLUID ISO 46 (1585 GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### Fluid Condition

The pH level of this fluid is within the acceptable limits at 8.0. The condition of the oil is acceptable for the time in service.

.)		NYLOLI MUQLO	21 1602022 00112022	Horee Haree Haree	3812.02.T	
SAMPLE INFORM	<b>MATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0038050	RP0042173	RP0042700
Sample Date		Client Info		11 Apr 2024	28 Mar 2024	12 Mar 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	10	<b>A</b> 36
Chromium	ppm	ASTM D5185m	>20	0	1	1
Nickel	ppm	ASTM D5185m	>20	0	1	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	12	10
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	0	<1	<1
Tin	ppm	ASTM D5185m	>20	0	1	<1
Vanadium	ppm	ASTM D5185m		0	1	<1
Cadmium	ppm	ASTM D5185m		0	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	3	2
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	5	0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	5	0	1	1
Calcium	ppm	ASTM D5185m	50	4	6	6
Phosphorus	ppm	ASTM D5185m	175	15	5	3
Zinc	ppm	ASTM D5185m	62	22	10	6
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	3	3
Sodium	ppm	ASTM D5185m		0	33	36
Potassium	ppm	ASTM D5185m	>20	0	7	8
Water	%	ASTM D6304	>55	34.8	36.3	35.7
ppm Water	ppm	ASTM D6304	>55000	348000	363000	357000
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	1122	548	565
Particles >6µm		ASTM D7647	>1300	611	298	308
Particles >14µm		ASTM D7647	>160	104	51	52
Particles >21µm		ASTM D7647	>40	35	17	18
Particles >38µm		ASTM D7647	>10	5	3	3
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/16/14	16/15/13	16/15/13

## Report Id: OUTCALAL [WUSCAR] 06147418 (Generated: 04/17/2024 19:33:49) Rev: 1








Sample Rating Trend





# **OIL ANALYSIS REPORT**












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	0.2%	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
pН	Scale 0-14	ASTM D1287		8.00	9.00	11.0
Visc @ 40°C	cSt	ASTM D445	46	59.7	59.3	59.3
SAMPLE IMAGES	5	method	limit/base	current	historv1	historv2

Color



Bottom



: 17 Apr 2024 - Jonathan Hester



To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: pH, ReserveAlk)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

Report Id: OUTCALAL [WUSCAR] 06147418 (Generated: 04/17/2024 19:33:49) Rev: 1

Certificate 12367

Laboratory

Sample No.

Unique Number : 10977496

Submitted By: DALE ROBINSON

Mario.johnson@outokumpu.com

Contact: MARIO JOHNSON

Page 2 of 2

F: x:

US 36513

T: (251)321-4105