




OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area
DICK LAVY
 Machine Id
DICK LAVY 4949
 Component
Rear Differential
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0900812	WC0843204	---
Sample Date	Client Info		15 Feb 2024	31 Jul 2023	---
Machine Age	mls	Client Info	56404	6280	---
Oil Age	mls	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	107	36	---
Chromium	ppm	ASTM D5185m >10	<1	<1	---
Nickel	ppm	ASTM D5185m >10	<1	0	---
Titanium	ppm	ASTM D5185m	<1	0	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >25	2	3	---
Lead	ppm	ASTM D5185m >25	<1	0	---
Copper	ppm	ASTM D5185m >100	2	0	---
Tin	ppm	ASTM D5185m >10	<1	0	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	<1	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	184	192	---
Barium	ppm	ASTM D5185m	0	0	---
Molybdenum	ppm	ASTM D5185m	<1	0	---
Manganese	ppm	ASTM D5185m	3	2	---
Magnesium	ppm	ASTM D5185m	6	1	---
Calcium	ppm	ASTM D5185m	19	13	---
Phosphorus	ppm	ASTM D5185m	1234	1113	---
Zinc	ppm	ASTM D5185m	7	0	---
Sulfur	ppm	ASTM D5185m	29862	30514	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	18	16	---
Sodium	ppm	ASTM D5185m	11	8	---
Potassium	ppm	ASTM D5185m >20	2	1	---
Water	%	ASTM D6304 >.2	0.028	0.082	---
ppm Water	ppm	ASTM D6304 >2000	290	827.6	---

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	▲ 128907	---
Particles >6µm	ASTM D7647	>5000	---	▲ 21801	---
Particles >14µm	ASTM D7647	>640	---	97	---
Particles >21µm	ASTM D7647	>160	---	20	---
Particles >38µm	ASTM D7647	>40	---	2	---
Particles >71µm	ASTM D7647	>10	---	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	▲ 24/22/14	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	▲ 3.76	● 3.55	---



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	LIGHT	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	NONE	---
Debris	scalar	*Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>.2	NEG	NEG	---
Free Water	scalar	*Visual		NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97.6	98.1	---
Visc @ 100°C	cSt	ASTM D445	14.6	14.8	---
Viscosity Index (VI)	Scale	ASTM D2270	155	157	---





SAMPLE IMAGES

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0900812 **Received** : 12 Apr 2024
Lab Number : 06148066 **Tested** : 17 Apr 2024
Unique Number : 10978144 **Diagnosed** : 17 Apr 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)