


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 8165996 (S/N 1037)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Aug/2022 Jun/2023 Apr/2024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016733	KCPA003309	KCP39789
Sample Date		Client Info		09 Apr 2024	08 Jun 2023	18 Aug 2022
Machine Age	hrs	Client Info		17001	10215	3426
Oil Age	hrs	Client Info		6700	0	3426
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	4	6
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	10	9	11
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	1	<1	3
Calcium	ppm	ASTM D5185m	2	4	3	0
Phosphorus	ppm	ASTM D5185m		0	4	2
Zinc	ppm	ASTM D5185m		0	9	2
Sulfur	ppm	ASTM D5185m		28384	22298	15944
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	3	<1
Sodium	ppm	ASTM D5185m		<1	1	2
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.05	0.007	0.003	<b>△</b> 0.313
ppm Water	ppm	ASTM D6304	>500	71	33.2	▲ 3130
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3504	27968	2532
Particles >6µm		ASTM D7647	>1300	850	<u></u> 10311	<b>△</b> 1379
Particles >14µm		ASTM D7647	>80	<b>140</b>	<b>△</b> 971	<u>^</u> 235
Particles >21µm		ASTM D7647	>20	<b>5</b> 0	<u>^</u> 236	<u>^</u> 79
Particles >38µm		ASTM D7647	>4	2	<u> </u>	<u>12</u>
Particles >71µm		ASTM D7647	>3	0	1	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>19/17/14</b>	<u>22/21/17</u>	<b>△</b> 19/18/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.51	0.52	0.38



## **OIL ANALYSIS REPORT**







Laboratory Sample No.

Lab Number

: 06148089

: KCPA016733 Unique Number: 10978167

Received : 12 Apr 2024 **Tested** : 15 Apr 2024 Diagnosed : 17 Apr 2024 - Jonathan Hester

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. 921 SHORE RD

SEMORA, NC US 27343 Contact: JACK LEMASYER

jack.lemasyer@saint.gobain.com

T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: