


OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id

7321521 (S/N 1069)Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb	2022	Aug2022 Mar207	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA105935	KCP49343	KCP40988
Sample Date		Client Info		25 Mar 2024	30 Aug 2022	15 Feb 2022
Machine Age	hrs	Client Info		10575	2924	1205
Oil Age	hrs	Client Info		1392	0	0
Oil Changed		Client Info		Changed	Changed	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	1	2	<1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	1
Barium	ppm	ASTM D5185m	90	31	0	25
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	75	45	47
Calcium	ppm	ASTM D5185m	2	6	0	0
Phosphorus	ppm	ASTM D5185m		0	0	4
Zinc	ppm	ASTM D5185m		4	0	0
Sulfur	ppm	ASTM D5185m		20717	21922	15712
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		23	16	7
Potassium	ppm	ASTM D5185m	>20	7	8	6
Water	%	ASTM D6304	>0.05	0.024	0.021	△ 0.315
ppm Water	ppm	ASTM D6304	>500	249	213.3	▲ 3150
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1795	2212	
Particles >6µm		ASTM D7647	>1300	407	348	
Particles >14µm		ASTM D7647	>80	35	16	
Particles >21µm		ASTM D7647	>20	10	6	
Particles >38µm		ASTM D7647	>4	1	1	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	18/16/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.34	0.33



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number

: 06148094

: KCPA105935 Unique Number : 10978172

Received : 12 Apr 2024 **Tested** : 15 Apr 2024

Diagnosed : 17 Apr 2024 - Jonathan Hester Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2000 E PECAN ST PFLUGERVILLE, TX

US 78660

Contact: Service Manager

T: F: Contact/Location: Service Manager - AMAPFL