


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SM 10 5981707 (S/N 1450)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	ourront	historya	hiotony
	MATION		iimiybase	current	history1	history2
Sample Number		Client Info		KCPA015072	KCP54086	
Sample Date		Client Info		20 Mar 2024	06 Jan 2023	
Machine Age	hrs	Client Info		6010	3210	
Oil Age	hrs	Client Info		2758	3210	
Oil Changed		Client Info		Not Changd	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	8	8	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		<1	0	
	ррпп		1::-			histow.O
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	<1	15	
Calcium	ppm	ASTM D5185m	0	3	0	
Phosphorus	ppm	ASTM D5185m	0	0	0	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	14832	20719	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		0	3	
Potassium	ppm	ASTM D5185m	>20	<1	0	
Water	%	ASTM D6304	>0.05	0.008	△ 0.697	
ppm Water	ppm	ASTM D6304	>500	88	△ 6970	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		34179		
Particles >6µm		ASTM D7647	>1300	14655		
Particles >14µm		ASTM D7647	>80	2057		
Particles >21µm		ASTM D7647	>20	^ 698		
Particles >38μm		ASTM D7647	>4	▲ 31		
Particles >71μm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>/17/13	22/21/18		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.39	



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KCPA015072 Received : 12 Apr 2024 Lab Number : 06148099

Tested : 15 Apr 2024 Unique Number: 10978177 Diagnosed : 17 Apr 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

105 SOUTH ST

US 06455

T:

F:

MIDDLEFIELD, CT

Contact: Service Manager