

OIL ANALYSIS REPORT



Machine Id

KAESER SFC 160 9000004 (S/N 1051)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		,		Apr2024		
SAMPLE INFORM	AATIONI		11 11 11		1111	1:
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130560		
Sample Date		Client Info		11 Apr 2024		
Machine Age	hrs	Client Info		2807		
Oil Age	hrs	Client Info		2807		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	2		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	2		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		38		
Zinc	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m	720	2		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304		0.003		
ppm Water	ppm	ASTM D6304	>500	29		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
	LOO	ASTM D7647	minu bass		inotory i	motory
Particles >4µm			. 1200	45898		
Particles >6µm		ASTM D7647 ASTM D7647		▲ 11398 ▲ 227		
Particles >14µm			>80	▲ 337 ▲ 94		
Particles >21µm Particles >38µm		ASTM D7647 ASTM D7647	>20 >4	<u></u> 94		
Particles >38µm Particles >71µm		ASTM D7647		<u>^</u> 5		
Oil Cleanliness		ISO 4406 (c)	>3 >/17/13			
		. ,				
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.20		



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No. Lab Number : 06148715 Unique Number : 10978793

: KC130560 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Apr 2024 **Tested** : 16 Apr 2024

Diagnosed : 16 Apr 2024 - Doug Bogart **PCC AIRFOILS - SMP PLANT** 29501 CLAYTON AVE WICKLIFFE, OH

US 44092 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: