




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**7352685 (S/N 1114)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) FG-460 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

**Wear**

All component wear rates are normal.

**Contamination**

Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KC130600</b>	KC130157	KC103587
Sample Date	Client Info			<b>06 Apr 2024</b>	14 Mar 2024	28 Dec 2022
Machine Age	hrs	Client Info		<b>12919</b>	12919	11791
Oil Age	hrs	Client Info		<b>1200</b>	0	5400
Oil Changed	Client Info			<b>Changed</b>	Not Changd	Changed
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>33</b>	24	3
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>6</b>	6	3
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>12</b>	10	17
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0




ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>2</b>	0	0
Calcium	ppm	ASTM D5185m		<b>2</b>	0	0
Phosphorus	ppm	ASTM D5185m	500	<b>269</b>	277	196
Zinc	ppm	ASTM D5185m		<b>242</b>	243	255

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	2
Sodium	ppm	ASTM D5185m		<b>3</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	0	1
Water	%	ASTM D6304	>0.05	<b>▲ 0.161</b>	0.00	0.022
ppm Water	ppm	ASTM D6304	>500	<b>▲ 1610</b>	0	223.0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>---</b>	16341	82710
Particles >6µm		ASTM D7647	>1300	<b>---</b>	▲ 4807	▲ 29985
Particles >14µm		ASTM D7647	>80	<b>---</b>	▲ 379	▲ 1249
Particles >21µm		ASTM D7647	>20	<b>---</b>	▲ 108	▲ 425
Particles >38µm		ASTM D7647	>4	<b>---</b>	3	▲ 61
Particles >71µm		ASTM D7647	>3	<b>---</b>	0	2
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>---</b>	▲ 21/19/16	▲ 24/22/17

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	<b>0.60</b>	0.66	0.55


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	46.8	46.5	46.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC130600  
**Lab Number** : 06148716  
**Unique Number** : 10978794  
**Test Package** : IND 2  
**Received** : 15 Apr 2024  
**Tested** : 17 Apr 2024  
**Diagnosed** : 17 Apr 2024 - Don Baldrige

**PIERRES ICE CREAM**  
 6200 EUCLID AVE  
 CLEVELAND, OH  
 US 44103  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)