


OIL ANALYSIS REPORT

EVAPORATORS MVR-F (S/N 11931)

Hydraulic System

PETRO CANADA PURITY FG AW HYDRAULIC 32 (250 GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

LIC 32 (250 GAL	.)	,	Apr2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM25507	USP242280	
Sample Date		Client Info		08 Apr 2024	21 Apr 2023	
Machine Age	yrs	Client Info		24	3	
Oil Age	yrs	Client Info		1	3	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	1	2	
Chromium	ppm	ASTM D5185m	>20	0	0	
Nickel	ppm	ASTM D5185m	>20	<1	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	0	<1	
Lead	ppm	ASTM D5185m	>20	0	0	
Copper	ppm	ASTM D5185m	>20	1	0	
Tin	ppm	ASTM D5185m	>20	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		1	0	
Calcium	ppm	ASTM D5185m		<1	0	
Phosphorus	ppm	ASTM D5185m		470	61	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		589	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	
Sodium	ppm	ASTM D5185m		2	0	
Potassium	ppm	ASTM D5185m		<1	0	
Water	%	ASTM D6304	>0.05	0.003	0.020	
ppm Water	ppm	ASTM D6304	>500	26	205.9	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	4977	11088	
Particles >6µm		ASTM D7647	>2500	947	2514	
Particles >14μm		ASTM D7647	>640	69	95	
Particles >21µm		ASTM D7647	>160	20	14	
Particles >38μm		ASTM D7647	>40	1	2	
Particles >71µm		ASTM D7647	>10	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/16	19/17/13	21/19/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.26	0.26	0.23	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: USPM25507 Lab Number : 06148729 Unique Number : 10978807 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Apr 2024

Tested : 16 Apr 2024 Diagnosed : 16 Apr 2024 - Doug Bogart KraftHeinz - Escalon - Plant 8384

1905 MCHENRY ESCALON, CA US 95320

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: KRAESC [WUSCAR] 06148729 (Generated: 04/16/2024 13:33:45) Rev: 1

Contact/Location: Service Manager - KRAESC

T:

F: