




# OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Machine Id  
**SL4-2 ASSET 9705 (S/N C1444000126)**  
 Component  
**Vacuum Pump**  
 Fluid  
**USPI 1580-125 (11 GAL)**

## DIAGNOSIS

### Recommendation

We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is above the recommended limit.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USP0006771</b>	USP0006758	USP0006760
Sample Date	Client Info		<b>10 Apr 2024</b>	08 Apr 2024	03 Apr 2024
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>541</b>	496	447
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>7</b>	9	28
Chromium	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >20	<b>0</b>	1	1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>1</b>	3	3
Lead	ppm	ASTM D5185m >20	<b>1</b>	1	1
Copper	ppm	ASTM D5185m >20	<b>2</b>	3	3
Tin	ppm	ASTM D5185m >20	<b>0</b>	1	1
Vanadium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	1	1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>14</b>	0	0
Barium	ppm	ASTM D5185m	<b>2</b>	<1	<1
Molybdenum	ppm	ASTM D5185m	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	1
Magnesium	ppm	ASTM D5185m	<b>1</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>2</b>	4	5
Phosphorus	ppm	ASTM D5185m	<b>1677</b>	1672	1429
Zinc	ppm	ASTM D5185m	<b>5</b>	8	9
Sulfur	ppm	ASTM D5185m	<b>1290</b>	970	879

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>▲ 81</b>	▲ 82	▲ 68
Sodium	ppm	ASTM D5185m	<b>1</b>	6	6
Potassium	ppm	ASTM D5185m >20	<b>6</b>	2	1
Water	%	ASTM D6304 >2.0	<b>0.402</b>	0.290	0.215
ppm Water	ppm	ASTM D6304 >20000	<b>4020</b>	2900	2152

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>638</b>	2250	187
Particles >6µm	ASTM D7647	>1300	<b>158</b>	680	57
Particles >14µm	ASTM D7647	>160	<b>29</b>	68	9
Particles >21µm	ASTM D7647	>40	<b>10</b>	21	4
Particles >38µm	ASTM D7647	>10	<b>0</b>	1	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>16/14/12</b>	18/17/13	15/13/10

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>▲ 3.85</b>	▲ 3.34	▲ 2.68




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.0	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	88.7	96.3	97.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USP006771 **Received** : 15 Apr 2024  
**Lab Number** : 06148740 **Tested** : 16 Apr 2024  
**Unique Number** : 10978818 **Diagnosed** : 16 Apr 2024 - Doug Bogart  
**Test Package** : IND 2

**CAMBRIA**  
 31496 CAMBRIA AVE  
 LE SUEUR, MN  
 US 56058  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)