

# **OIL ANALYSIS REPORT**

[419116]

# ATLAS COPCO API1277260 - BEST TOY LTD

Component Compressor





#### Recommendation

The oil change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

Moderate concentration of visible dirt/debris present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06148794		
Sample Date		Client Info		03 Apr 2024		
Machine Age	hrs	Client Info		1223		
Oil Age	hrs	Client Info		623		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		2		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		<1		
Phosphorus	ppm	ASTM D5185m		29		
Zinc	ppm	ASTM D5185m		36		
Sulfur	ppm	ASTM D5185m		115		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	31		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.09		





## **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	MODER		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		46.6		
SAMPLE IMAGES		method	limit/base	current	history1	history2
	<i></i>	memou	IIIIII/Dase	Carrent	Thistory	Thistory Z
Color	3	method	IIIIII/Dase	Gardin	no image	no image
		memod	iiiiivoase			
Color		memod	iiiiivoase	ound it	no image	no image
Color		memod	iiiiivoase	ound it	no image	no image
Color  Bottom  GRAPHS		method	iiiiii base		no image	no image











Laboratory Sample No.

Lab Number : 06148794

: UCH06148794  $\textbf{Unique Number} \quad : 10978872$ 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Apr 2024

**Tested** : 16 Apr 2024 Diagnosed

: 17 Apr 2024 - Sean Felton

US 07072 Contact: ELVIN DIAZ ediaz@airmaticcompressor.com;canastasio@wearcheckusa.com

**AIRMATIC COMPRESSOR SYSTEMS** 

700 WASHINGTON AVE

CARLSTADT, NJ

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (800)864-7621 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (201)342-6241

Contact/Location: ELVIN DIAZ - UCAIRCAR

Report Id: UCAIRCAR [WUSCAR] 06148794 (Generated: 04/17/2024 21:42:17) Rev: 1