

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **NOT** GIVEN [417590] ATLAS COPCO ITJ425420 Component Compressor

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06148796		
Sample Date		Client Info		14 Apr 2024		
Machine Age	hrs	Client Info		1187		
Oil Age	hrs	Client Info		1187		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		6		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	3		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		50		
Zinc	ppm	ASTM D5185m		71		
Sulfur	ppm	ASTM D5185m		186		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	<1		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.16		



OIL ANALYSIS REPORT



	VISUAL		method				history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	LIGHT			
4	Sand/Dirt	scalar	*Visual	NONE	NONE			
Apr14/24	Appearance	scalar	*Visual	NORML	NORML			
4	Odor Emulsified Water	scalar	*Visual	NORML	NORML NEG			
	Free Water	scalar scalar	*Visual *Visual	>0.1	NEG			
	FLUID PROPERT			line it //e e e e				
	Visc @ 40°C	cSt	method ASTM D445	limit/base	current 46.5	history1	history2	
				l:				
4/24	SAMPLE IMAGES	>	method	limit/base	current	history1 no image	history2 no image	
Apr14/24	Bottom					no image	no image	
	Non-ferrous Metals			Apri4/24				
	Viscosity @ 40°C			Apr14/24				
	Abnormal 40 40 40 40 40 40 40 40 40 40			(0,0.20 (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (0,0.11) (Acid Number			
	Apr14,24			Apr14/24	Apr14/24		April 4/24	
Laboratory Sample No. Lab Number Unique Number rtificate L2367 Test Package	: UCH06148796 : <mark>06148796</mark> : 10978874	Received: 15 Apr 2024Tested: 16 Apr 2024Diagnosed: 17 Apr 2024 - Sean Felton				ATIC COMPRESSOR SYSTEMS 700 WASHINGTON AVE CARLSTADT, N US 0707 Contact: ELVIN DIA naticcompressor.com;canastasio@wearcheckusa.co T: (800)864-762		

Contact/Location: ELVIN DIAZ - UCAIRCAR