OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
MTNM01BE
Component
Biogas Engine
Fluid
SHELL MYSELLA S5 N 40 (160 GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. (Customer Sample Comment: As stated on paper note section we were hoping to do soot testing or additional testing to see why it's so dark in such a short amount of time.)

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0775219**	WC0775217	WC0775214
Sample Date		Client Info		**10 Apr 2024**	01 Apr 2024	26 Mar 2024
Machine Age	hrs	Client Info		**42071**	41990	41861
Oil Age	hrs	Client Info		**75**	143	14
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	**<1.0**	<1.0	<1.0
Water		WC Method		**NEG**	NEG	NEG
Glycol		WC Method		**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>14	**1**	4	3
Chromium	ppm	ASTM D5185m	>3	**0**	0	0
Nickel	ppm	ASTM D5185m		**0**	<1	<1
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>5	**2**	3	3
Lead	ppm	ASTM D5185m	>8	**0**	0	0
Copper	ppm	ASTM D5185m	>5	**<1**	<1	<1
Tin	ppm	ASTM D5185m	>3	**0**	2	1
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	4	4
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**2**	5	4
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m		**11**	37	25
Calcium	ppm	ASTM D5185m		**1427**	1706	1488
Phosphorus	ppm	ASTM D5185m	300	**279**	361	301
Zinc	ppm	ASTM D5185m		**317**	435	390
Sulfur	ppm	ASTM D5185m		**2960**	3934	3399

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>180	**47**	167	99
Sodium	ppm	ASTM D5185m	>20	**2**	1	1
Potassium	ppm	ASTM D5185m	>20	**0**	0	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		**0.1**	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>16	**3.7**	4.9	4.2
Sulfation	Abs/.1mm	*ASTM D7415		**18.3**	22.0	19.4

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		**11.3**	15.0	12.8
Acid Number (AN)	mg KOH/g	ASTM D8045	0.5	**0.75**	1.48	0.67
Base Number (BN)	mg KOH/g	ASTM D2896	4.9	**3.88**	3.30	4.17

OIL ANALYSIS REPORT

FT-IR (Direct Trend)



Acid Number



Base Number



Viscosity @ 100°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual		**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	**13.2**	13.8	13.4

GRAPHS

Iron (ppm)



Lead (ppm)



Aluminum (ppm)



Chromium (ppm)



Copper (ppm)



Silicon (ppm)



Viscosity @ 100°C



Base Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0775219
Lab Number : 06148889
Unique Number : 10978967
Test Package : MOB 2

Received : 15 Apr 2024
Tested : 16 Apr 2024
Diagnosed : 24 Apr 2024 - Jonathan Hester

Certificate L2367

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

EDL NA Recips-Morgantown
Morgantown Powerstation, 950 Shiloh
Morgantown, PA
US 19543
Contact: ARON GUNN
aron.gunn@edlenergy.com
T:
F:

Report Id: EDLMOR [WUSCAR] 06148889 (Generated: 04/24/2024 08:51:05) Rev: 1

Submitted By: LANDON WEBER