




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
2392672 (S/N 1021)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCPA015711 | KCPA001431 | KCP46749D |
| Sample Date | Client Info | | | 15 Mar 2024 | 20 Mar 2023 | 12 Oct 2022 |
| Machine Age | hrs | Client Info | | 0 | 27514 | 23968 |
| Oil Age | hrs | Client Info | | 0 | 0 | 3164 |
| Oil Changed | Client Info | | | Changed | N/A | Not Changd |
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|----------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 2 | 3 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 13 | 10 |
| Copper | ppm | ASTM D5185m | >50 | 3 | 6 | 5 |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |






| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 90 | 93 | 115 | 77 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 90 | 99 | 137 | 114 |
| Calcium | ppm | ASTM D5185m | 2 | 23 | 4 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 10 | 4 | 16 |
| Zinc | ppm | ASTM D5185m | | 8 | 0 | 0 |
| Sulfur | ppm | ASTM D5185m | | 15012 | 18011 | 19253 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | <1 | <1 |
| Sodium | ppm | ASTM D5185m | | 20 | 19 | 18 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 4 | 2 |
| Water | % | ASTM D6304 | >0.05 | 0.019 | 0.026 | 0.013 |
| ppm Water | ppm | ASTM D6304 | >500 | 192 | 264.1 | 133.8 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|-------------------|------------|------------|
| Particles >4µm | | ASTM D7647 | | 7693 | 10959 | 8767 |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 1895 | ▲ 3113 | ● 2283 |
| Particles >14µm | | ASTM D7647 | >80 | ▲ 205 | ▲ 176 | ▲ 179 |
| Particles >21µm | | ASTM D7647 | >20 | ▲ 57 | ▲ 38 | ▲ 50 |
| Particles >38µm | | ASTM D7647 | >4 | 2 | 3 | 2 |
| Particles >71µm | | ASTM D7647 | >3 | 1 | 0 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ 20/18/15 | ▲ 21/19/15 | ▲ 20/18/15 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.49 | 0.47 | 0.40 |


OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | LIGHT |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46 | 47.6 | 55.4 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA015711 **Received** : 15 Apr 2024
Lab Number : 06149515 **Tested** : 16 Apr 2024
Unique Number : 10979593 **Diagnosed** : 17 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

NORTHROP GRUMMAN
 11310 FREDERICK AVE
 BELTSVILLE, MD
 US 20705
 Contact: VINCENT PEYTON
 VINCENT.PEYTON@NGC.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)